

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
NSA MID-SOUTH Play Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			9/30/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/14/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	MDS-1903-PLAY-WFBA-FD (PA-1)	Splash Park Stand alone fountain by soda machine/restrooms	1.3	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-1903-PLAY-WFBB-FD (PA-2)	Splash Park Attached fountains on west side of splash pad, left	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-1903-PLAY-WFBC-FD (PA-3)	Splash Park Attached fountains on west side of splash pad, middle	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-1903-PLAY-WFBD-FD (PA-4)	Splash Park Attached fountains on west side of splash pad, right	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-1784-PLAY-WFBD-FD (PA-5)	Baseball Field Across Splash Park - Fountain attached to restroom building	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-499-PLAY-WFBA-FD (PA-6)	Basketball Courts Across from Fitness Center -High/Low Combination Fountain, left low fountain	9.7	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-499-PLAY-WFBB-FD (PA-7)	Basketball Courts Across from Fitness Center -High/Low Combination Fountain, right high fountain	8.4	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	MDS-499-PLAY-WFBC-FD (PA-8)	Basketball Courts Across from Fitness Center - Stand Alone Fountain	1.4	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Notes:

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
NSA MID-SOUTH Play Areas

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	8	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	8	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0