



## ***2013 Annual Drinking Water Quality Report***

### **NAVAL AIR STATION WHITING FIELD**

In 2013, Naval Air Station Whiting Field detected 15 contaminants – none above the EPA acceptable level. This report will be mailed to customers only upon request from the Naval Air Station (NAS) Whiting Field's Public Works Department by calling (850) 665-6169. This report will be posted on the Naval Air Station Whiting Field Internet site located at [www.cnic.navy.mil/regions/cnrse/installations/nas\\_whiting\\_field.html](http://www.cnic.navy.mil/regions/cnrse/installations/nas_whiting_field.html) and hard copies will be available at the Public Works Department (Building 1416), the Pass/Tag office (Building 48), and the Navy Gateway Inns & Suites/Sikes Hall (Building 2942).

*We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is ground water from three (3) wells. The wells draw from the Sand and Gravel Aquifer, at a depth of 216 ft. Because of the excellent quality of our water, the only treatments required are chlorine for disinfection purposes, sodium hydroxide for pH adjustment, phosphate for lead and copper prevention, fluoride for dental health purposes and granulated activated charcoal for additional protection.*

*Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.*

*If you have any questions about this report or concerning your water utility, please contact **Mike Pattison, Environmental Director, NASWF Public Works Department (850) 623-7017** about their water utility.*

*NAS Whiting Field routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2013. Data obtained before January 1, 2013 and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.*

*NAS Whiting Field's test results do not indicate elevated levels of lead. However, if present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NAS WHITING FIELD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.*

*In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:*

*Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*

*Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*

*Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.*

*Initial Distribution System Evaluation (IDSE): An important part of the Stage 2 Disinfection Byproducts Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.*

*Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.*

*Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.*

*Million fibers per liter (MFL): measure of the presence of asbestos fibers that are longer than 10 microfibers.*

*"ND" means not detected and indicates that the substance was not found by laboratory analysis.*

*Parts per billion (ppb) or Micrograms per liter (µg/l) – one part by weight of analyte to 1 billion parts by weight of the water sample.*

*Parts per million (ppm) or Milligrams per liter (mg/l) – one part by weight of analyte to 1 million parts by weight of the water sample.*

*Picocurie per liter (pCi/L) - measure of the radioactive in water.*

### 2013 CONTAMINANTS TABLE

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>							
Alpha emitters (pCi/L)	July-08	N	0.9	ND-0.9	0	15	Erosion of natural deposits
<b>Inorganic Contaminants</b>							
Arsenic (ppb)	June-12	N	0.6	ND-0.6	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Asbestos (MFL)	Jul-12	N	1	N/A	7	7	Decay of asbestos cement water mains; erosion of natural deposits
Barium (ppm)	June-12	N	0.013	0.0062-0.013	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	June-12	N	0.83	0.37-0.83	4	4.0	Likely Source of Contamination: Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm.
Lead (point of entry) (ppb)	June-12	N	0.1	ND-0.1	0	15	Residue from man-made pollution such as auto emissions and paint; lead pipe, casing and solder
Mercury (inorganic) (ppb)	June-12	N	0.1	ND-0.1	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (as Nitrogen) (ppm)	June-13	N	0.69	0.48-0.69	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	June-12	N	1.1	ND – 1.1	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	June-12	N	40	30-40	N/A	160	Salt water intrusion, leaching from soil

Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
<b>Stage 1 Disinfectants and Disinfection By-Products</b>							
Chlorine (ppm)	Jan-Dec 13	N	0.58	0.42-0.64	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	Jul-12	N	0.76	N/A	N/A	MCL = 60	By-product of drinking water disinfection
TTHM [Total trihalomethanes] (ppb)	Jul-12	N	2.29	N/A	NA	MCL = 80	By-product of drinking water disinfection

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Exceeded Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
<b>Lead and Copper (Tap Water)</b>							
Copper (tap water) (ppm)	June-Sept 13	N	0.33	0 of 20	.36	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	June-Sept. 13	N	2.3	0 of 20	.0017	15	Corrosion of household plumbing systems, erosion of natural deposits

*The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.*

*Contaminants that may be present in source water include:*

- (A) *Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- (B) *Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.*
- (C) *Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.*
- (D) *Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban stormwater runoff, and septic systems.*
- (E) *Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.*

*In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.*

*In 2013 the Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There are 2 potential sources of contamination identified for this system with a moderate susceptibility levels. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp) or they can be obtained from NAS Whiting Field Public Works Department.*

***Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).***

*We at NAS Whiting Field would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to insuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed.*