

2008 Annual Drinking Water Quality Report NAS Pensacola Saufley Field

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is ground water from 33 Emerald Coast Utility Authority wells. The wells draw from the Sand and Gravel Aquifer. In general, Saufley Field Water System customers receive water from ECUA wells closest to our system. As such, the water delivered to customers is usually a blend of water from more than one well. Each well is considered a separate treatment plant, where water quality parameters are adjusted to comply with operating standards. Calcium Hydroxide (lime) is added for pH adjustment; Phosphoric Acid (H₃PO₄) is added for corrosion control in the distribution system and Chlorine gas (Cl₂) is added for water disinfection. Granular Activated Carbon (GAC) filters are installed on twelve wells, nine for organic contamination removal and three for iron removal. Hydrofluosilic Acid (H₂SiF₆) is added, at select wells, as a source of fluoride treatment for the entire system.

The recharge area for ECUA wells is limited to the area of Escambia County, south of Cantonment. Because the Sand and Gravel Aquifer does not have a confining layer above it, virtually everything that falls on the ground has the potential to reach the main producing zone of the aquifer and affect the quality of our water supply. This concern is referenced in the NORTHWEST FLORIDA WATER MANAGEMENT DISTRICT Public Information Bulletin 87-2, March 1990 and again, in the Escambia County 2004 Grand Jury Report on Groundwater Contamination. This report can be reviewed on line at: [www.clerk.co.escambia.fl.us/downloads/2004Grand Jury Ground Water Contamination.tif](http://www.clerk.co.escambia.fl.us/downloads/2004Grand%20Jury%20Ground%20Water%20Contamination.tif).

ECUA is well aware of this threat to the groundwater and over the years has worked with Escambia County and the City of Pensacola in strengthening their Wellhead Protection Ordinances. For more specific information concerning each well, please contact the ECUA. The tables in this report contain data from ECUA's water quality testing. In addition, our system tests for microbiological contaminants, disinfectant and disinfection by products and also tests for lead and copper.

If you have any questions about this report or concerning your water utility, please contact William Taylor at 452-3131 x3003. We encourage our valued customers to be informed about their water utility.

Emerald Coast Utility Authority and the Naval Air Station Pensacola routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2008. Data obtained before January 1, 2008, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

The ECUA has been monitoring for unregulated contaminants (UCs) as part of a study to help the U.S. Environmental Protection Agency (EPA) determine the occurrence in drinking water of UCs and whether or not these contaminants need to be regulated. At present, no health standards (for example, maximum contaminant levels) have been established for UCs. However, we are required to publish the analytical results of our UC monitoring in our annual water quality report. If you would like more information on the EPA's Unregulated Contaminants Monitoring Rule, please call the Safe Drinking Water Hotline at (800) 426-4791.

The FDEP conducted a statewide assessment of public drinking water systems in 2004. ECUA and Saufley Field's systems were not assessed at that time.

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

Initial Distribution System Evaluation (IDSE): An important part of the Stage 2 Disinfection Byproducts Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

“ND” means not detected and indicates that the substance was not found by laboratory analysis.

Parts per million (ppm) or Milligrams per liter (mg/l) – one part by weight of analyte to 1 million parts by weight of the water sample.

Parts per billion (ppb) or Micrograms per liter (µg/l) – one part by weight of analyte to 1 billion parts by weight of the water sample.

Pico curie per liter (pCi/L) - measure of the radioactivity in water.

2008 CONTAMINANTS TABLE

Microbiological Contaminants						
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Highest Monthly Percentage/Number	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria*	Jan-Dec 08	N	4.7%	0	For systems collecting at least 40 samples per month: presence of coliform bacteria in 5% of monthly samples.	Naturally present in the environment

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Radiological Contaminants							
Alpha emitters (pCi/L)	Jan-Dec 08	N	6.0	ND-6.0	0	15	Erosion of natural deposits
Radium 226 + 228 or combined radium (pCi/L)	Jan-Dec 08	N	5.0	0.1-5.0	0	5	Erosion of natural deposits
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants							
Barium (ppm)	Jan-Dec 08	N	0.5	ND-0.5	2	2	Erosion of natural deposits
Cadmium (ppb)	Jan-Dec 08	N	0.6	ND-0.6	5	5	Erosion of natural deposits
Chromium (ppb)	Jan-Dec 08	N	0.7	ND-0.7	100	100	Erosion of natural deposits
Cyanide (ppb)	Jan-Dec 08	N	9.0	ND-9.0	200	200	Erosion of natural deposits
Fluoride (ppm)	Jan-Dec 08	N	0.8	ND-0.8	4	4.0	Water additive which promotes strong teeth
Lead (ppb)	Jan-Dec 08	N	1.1	ND-1.1	n/a	15	Erosion of natural deposits r
Mercury (inorganic) (ppb)	Jan-Dec 08	N	0.2	ND-0.2	2	2	Erosion of natural deposits; runoff from landfills
Nickel (ppb)	Jan-Dec 08	N	1.0	ND-1.0	N/A	100	Erosion of natural deposits; surface runoff
Nitrate (as Nitrogen) (ppm)	Jan-Dec 08	N	4.4	ND-4.4	10	10	Erosion of natural deposits; surface runoff
Sodium (ppm)	Jan-Dec 08	N	9.2	ND-9.2	N/A	160	Salt water intrusion
Volatile Organic Contaminants							
1,1 – Dichloroethylene (ppb)	Jan-Dec 08	N	1.47 (annual average)	ND-1.73	7	7	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	Jan-Dec 08	N	1.26 (annual average)	ND-3.19	0	3	Discharge from factories and dry cleaners
Trichloroethylene (ppb)	Jan-Dec 08	N	1.94 (annual average)	ND-2.26	0	3	Discharge from metal degreasing sites and other factories
Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Stage 1 Disinfectants and Disinfection By-Products							
Chlorine (ppm)*	Jan-Dec 08	N	1.07 (annual average)	0.5-1.9	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
TTHM [Total trihalomethanes] (ppb) *	Jul 08	N	4.8	NA	NA	MCL = 80	By-product of drinking water disinfection

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Violation Y/N	90 th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Lead and Copper (Tap Water)							
Copper (tap water) (ppm)*	June-July 06	N	0.038	0 of 20	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)*	June-July 06	N	8.7	1 of 20	0	15	Corrosion of household plumbing systems, erosion of natural deposits

*Contaminant data marked with an asterisk are obtained from wells on NAS Saufley Field only, all other contaminant data is from ECUA wells.

Unregulated Organic Contaminants

Reasons for monitoring unregulated contaminants: a) To determine appropriate MDL's for the unregulated contaminants and b) To evaluate which compounds should be regulated.

Contaminant and Unit of Measurement	Dates of sampling	Average Result	Range of Results at or above detection	Likely Source of Contamination
1,1-Dichloroethane (ppb)	Jan-Dec- 08	0.0025 (annual average)	ND-0.1	Leaching from gasoline storage tanks
Dibromochloromethane (ppb)	Jan-Dec- 08	0.0009 (annual average)	ND-0.21	By-products of drinking water chlorination
Methyl tert-butyl-ether (ppb) (MTBE)	Jan-Dec- 08	0.430 (annual average)	ND-5.54	Leaching from gasoline storage tanks
Chloroform (ppb)	Jan-Dec- 08	0.05 (annual average)	ND-0.53	By-products of drinking water chlorination
Bromodichloromethane (ppb)	Jan-Dec- 08	0.0004 (annual average)	ND-0.1	By-products of drinking water chlorination
Trichlorofluoromethane	Jan-Dec- 08	0.0006 (annual average)	ND-0.15	By-products of drinking water chlorination

The Saufley Field Water System had a monthly total coliform sample test positive for bacteria in January. It was immediately retested with all repeats testing negative. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. When coliforms are found in more samples than allowed there is a warning of potential problems. DEP regulations require 5 samples to be run the following month after any positive distribution sample. Due to an oversight, Saufley Field Water System collected only two samples the following month. DEP notified Saufley Field Water System that this system was in violation and was required to issue a public notification to this effect. The sampling plan for this system was reviewed and modified to ensure that this mistake will not happen again.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Saufley Field is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it

dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.*
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.*
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.*
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.*

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).