

PRIORITY AREAS LEAD TESTING AND CORRECTIVE ACTIONS (OCTOBER 2014)  
 JBPBH WAHIAWA ANNEX CHILD DEVELOPMENT CENTER  
 BUILDING 477

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS		CORRECTIVE ACTIONS	POST-REMEDATION SAMPLING		COMMENTS
				Recommended Level = 20 ppb						Recommended Level = 20 ppb		
SAMPLE ID	FLOOR PLAN NO.	ROOM NO.	Outlet Description	First Draw (ppb)	Retest Required?	Date Fixture Secured?	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Retest required?	
<b>SAMPLING DATE</b>				10/18/2014			11/13/2014			1/8/2015		
<b>RESULTS DATE</b>				11/6/2014			11/24/2014			2/6/2015		
NC-477-1-120-K	1	120	Adult Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-2-119-K	2	119	Adult Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-3-118-K	3	118	Adult Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-4-118-HWCOMB	4	118	Toddler Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-5-118-WFCOMB	5	118	Toddler Water Fountain	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-6-117-K	6	117	Adult Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-7-117-HWCOMB	7	117	Toddler Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-8-117-WFCOMB	8	117	Toddler Water Fountain	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-9-116-HHW	9	116	Adult Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-10-116-HWCOMB	10	116	Toddler Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-11-116-WFCOMB	11	116	Toddler Water Fountain	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-12-113-K	12	113	Adult Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-13-107-HHW	13	107	Kitchen Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-14-107-K	14	107	Kitchen Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-15-107-HHW	15	107	Kitchen Sink	11.6	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-16-107-K	16	107	Kitchen Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-17-107-K	17	107	Kitchen Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-19-107-K	19	107	Kitchen Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-20-107-K	20	107	Kitchen Sink	<5	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-21-EXT-HB	21	Exterior	Hose Bib	9.63	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-22-EXT-HB	22	Exterior	Hose Bib	15.4	No	N/A	N/A	N/A	N/A	N/A	N/A	
NC-477-23-EXT-HB	23	Exterior	Hose Bib	26.4	Yes	11/12/2014	11.7	<5	Fixture replaced	<5	No	Remediation completed