

**Mandatory Language for Monitoring and Reporting Violation
Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The **Naval Air Station Corpus Christi** water system PWS ID **TX1780017** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period 2nd Quarter 2019: April 1 to June 30, 2019.

We are taking the following actions to address this issue:

NASCC failed to submit the required Disinfectant Level Quarterly Operating Report by the due date per 30 TAC Chapter 290.110 (e)(4)(A) and 30 TAC Chapter 290.110(f)(3) for April through June 2019. Only one Certified Public Water System Operator was enrolled in the TCEQ online reporting system and was on extended leave from work when the report was due. Public notice is required to inform personnel about the reporting violation within one calendar year. The Disinfectant Level Quarterly Operating Report was submitted online on 11 October 2019 by the Certified Public Water System Operator. In order to ensure that future reports are submitted on time, an additional Certified Public Water System Operator was enrolled in the TCEQ online reporting system in accordance with 30 TAC 290.46(f)(4)(C) and 30 TAC 19.12(c) to serve as a backup.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Biji Pandisseril, Environmental Program Director at 361-961-5353.

Posted /Delivered on: June 4, 2020