

Priority Areas Lead Testing and Corrective Actions May 2018
Naval Air Station Mayport Child Development Center Building 2287

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 20ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy
DRINKING	MYP-2287-RM147-PLAY-WFB-FD (BLDG 2287-8)	Pre-Toddler 5 Outdoor play area	3.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-HALL-RM117-WFC-A-FD (BLDG 2287-24)	Hallway Outside of Room 117 High fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-HALL-RM117-WFC-B-FD (BLDG 2287-25)	Hallway Outside of Room 117 Low fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-RM112-PLAY-WFB-FD (BLDG 2287-39)	Pre-toddler 1 Outside play area	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-RM123-PLAY-WFB-A-FB (BLDG 2287-57)	Preschool 2 Playground/Right side	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-RM123-PLAY-WFB-B-FD (BLDG 2287-58)	Preschool 2 Playground/Left side	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-RM127-PLAY-WFB-FD (BLDG 2287-71)	Toddler 3 Play area outside Rm 127	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MYP-2287-RM129-PLAY-WFB-FD (BLDG 2287-72)	Toddler 2 Play area outside Rm 129	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING/TEETHBRUSHING	MYP-2287-RM120-RM-WFB-FD (BLDG 2287-47)	Preschool 1 Teeth brushing fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING/TEETHBRUSHING	MYP-2287-RM123-RM-WFB-FD (BLDG 2287-56)	Preschool 2 Teeth brushing fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING/TEETHBRUSHING	MYP-2287-RM125-RM-WFB-FD (BLDG 2287-64)	VPK-3 Teeth brushing fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING/TEETHBRUSHING	MYP-2287-RM127-RM-WFB-FD (BLDG 2287-68)	Toddler 3 Teeth brushing fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING/TEETHBRUSHING	MYP-2287-RM129-RM-WFB-FD (BLDG 2287-74)	Toddler 2 Teeth brushing fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING/TEETHBRUSHING	MYP-2287-RM132-RM-WFB-FD (BLDG 2287-82)	Toddler 1 Teeth brushing fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MYP-2287-RM138-LOUNGE-K-FD (BLDG 2287-1)	Staff Lounge First water draw in AM	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions May 2018
Naval Sir Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			Recommended Level = 20ppb							Recommended Level = 20ppb	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/5/2018				mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy
			RESULTS DATE				5/30/2018	mm/dd/yyyy			mm/dd/yyyy
COOKING	MYP-2287-RM148-K-K-A-FD (BLDG 2287-10)	Kitchen Stainless steel sink	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MYP-2287-RM148-K-HHW-A-FD (BLDG 2287-11)	Kitchen Stainless steel handwashing sink	5.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MYP-2287-RM148-K-K-B-FD (BLDG 2287-12)	Kitchen Stainless steel sink	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MYP-2287-RM148-K-K-C-FD (BLDG 2287-13)	Kitchen Triple stainless steel sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MYP-2287-RM148-K-HHW-B-FD (BLDG 2287-14)	Kitchen Stainless steel handwashing sink by the door	2.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-UBATH-RM141- MSHHW-FD (BLDG 2287-2)	Unisex Bathroom Motion sensor faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM144-RM-HHW-A- FD (BLDG 2287-3)	Infant Room Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM144-RM-HHW-B- FD (BLDG 2287-4)	Infant Room Foot pedal	0.84	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM144-RM-MSLHW- FD (BLDG 2287-5)	Infant Room Motion sensor faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM147-RM-HHW-B- FB (BLDG 2287-6)	Pre-Toddler 5 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM147-RM-HHW-A- FD (BLDG 2287-7)	Pre-Toddler 5 Foot pedal	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM147-RM-MSLHW- FD (BLDG 2287-9)	Pre-Toddler 5 Motion sensor faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM155-RM-HHW-A- FD (BLDG 2287-15)	Infant Room 6 Foot pedal	1.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM155-RM-HHW-B- FD (BLDG 2287-16)	Infant Room 6 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM155-RM-MSLHW- FD (BLDG 2287-17)	Infant Room 6 Motion sensor faucet	8.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM156-RM-HHW-B- FD (BLDG 2287-18)	Infant Room 5 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions May 2018
 Naval Sir Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Description	Recommended Level = 20ppb
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	MYP-2287-RM156-RM-HHW-A-FD (BLDG 2287-19)	Infant Room 5 Foot pedal	0.85	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM156-RM-MSLHW-FD (BLDG 2287-20)	Infant Room 5 Motion sensor faucet	5.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM159-RM-HHW-A-FD (BLDG 2287-21)	Infant Room 4 Foot pedal	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM159-RM-HHW-B-FD (BLDG 2287-22)	Infant Room 4 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM159-RM-MSLHW-FD (BLDG 2287-23)	Infant Room Motion sensor faucet	11	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-UBATH-MSHHW-A-FD (BLDG 2287-26)	Unisex bthrm across 117 Motion sensor faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-UBATH-MSHHW-B-FD (BLDG 2287-27)	Unisex bthrm across 118 Motion sensor faucet	0.81	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM105-RM-HHW-A-FD (BLDG 2287-28)	Infant Room 3 Foot pedal	0.76	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM105-RM-HHW-B-FD (BLDG 2287-29)	Infant Room 3 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM105-RM-MSLHW-FD (BLDG 2287-30)	Infant Room 3 Motion sensor faucet	3.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM107-RM-HHW-A-FD (BLDG 2287-31)	Infant Room 2 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM107-RM-HHW-B-FD (BLDG 2287-32)	Infant Room 2 Foot pedal	0.72	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM107-RM-MSLHW-FD (BLDG 2287-33)	Infant Room 2 Motion sensor faucet	6.4	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions May 2018
Naval Sir Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	MYP-2287-RM108-RM-HHW-A-FD (BLDG 2287-34)	Infant Room 1 Foot pedal	0.76	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM108-RM-HHW-B-FD (BLDG 2287-35)	Infant Room 1 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM112-RM-HHW-A-FD (BLDG 2287-37)	Pre-toddler 1 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM112-RM-HHW-B-FD (BLDG 2287-38)	Pre-toddler 1 Foot pedal	0.87	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM113-RM-HHW-A-FD (BLDG 2287-40)	Pre-toddler 2 Foot pedal	0.96	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM113-RM-HHW-B-FD (BLDG 2287-41)	Pre-toddler 2 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM115-RM-HHW-A-FD (BLDG 2287-42)	Pre-toddler 3 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM115-RM-HHW-B-FD (BLDG 2287-43)	Pre-toddler 3 Foot pedal	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM115-RM-MSLHW-FD (BLDG 2287-44)	Pre-toddler 3 Motion sensor faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM120-RM-HHW-A-FD (BLDG 2287-45)	Preschool 1 Foot pedal	2.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM120-RM-HHW-B-FD (BLDG 2287-46)	Preschool 1 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM120-RM-LHW-FD (BLDG 2287-48)	Preschool 1 Sink faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM120-RM-MSLHW-A-FD (BLDG 2287-49)	Preschool 1 Motion sensor faucet	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM120-RM-MSLHW-B-FD (BLDG 2287-50)	Preschool 1 Motion sensor faucet	0.86	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM123-RM-LHW-FD (BLDG 2287-51)	Preschool 2 Sink faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions May 2018
Naval Sir Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	MYP-2287-RM123-RM-MSLHW-A-FD (BLDG 2287-52)	Preschool 2 Motion sensor faucet	0.82	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM120-RM-MSLHW-B-FD (BLDG 2287-53)	Preschool 2 Motion sensor faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM123-RM-HHW-A-FD (BLDG 2287-54)	Preschool 2 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM123-RM-HHW-B-FD (BLDG 2287-55)	Preschool 2 Foot pedal	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM125-RM-MSLHW-A-FD (BLDG 2287-59)	VPK-3 Motion sensor faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM125-RM-MSLHW-B-FD (BLDG 2287-60)	VPK-3 Motion sensor faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM125-RM-HHW-A-FD (BLDG 2287-61)	VPK-3 Foot pedal	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM125-RM-HHW-B-FD (BLDG 2287-62)	VPK-3 Kitchen faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM125-RM-LHW-FD (BLDG 2287-63)	VPK-3 Sink faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM127-RM-HHW-A-FD (BLDG 2287-65)	Toddler 3 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM127-RM-HHW-B-FD (BLDG 2287-66)	Toddler 3 Foot pedal	2.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM127-RM-LHW-FD (BLDG 2287-67)	Toddler 3 Sink faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM127-RM-MSLHW-A-FD (BLDG 2287-69)	Toddler 3 Motion sensor faucet	0.8	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions May 2018
 Naval Air Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	MYP-2287-RM127-RM-MSLHW-B-FD (BLDG 2287-70)	Toddler 3 Motion sensor faucet	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM129-RM-LHW-FD (BLDG 2287-73)	Toddler 2 Sink faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM129-RM-HHW-A-FD (BLDG 2287-75)	Toddler 2 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM129-RM-HHW-B-FD (BLDG 2287-76)	Toddler 2 Foot pedal	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM129-RM-MSLHW-A-FD (BLDG 2287-77)	Toddler 2 Motion sensor faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM129-RM-MSLHW-B-FD (BLDG 2287-78)	Toddler 2 Motion sensor faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM132-RM-HHW-A-FD (BLDG 2287-79)	Toddler 1 Foot pedal	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM132-RM-HHW-B-FD (BLDG 2287-80)	Toddler 1 Kitchen faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM132-RM-LHW-FD (BLDG 2287-81)	Toddler 1 Sink faucet	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM132-RM-MSLHW-A-FD (BLDG 2287-83)	Toddler 1 Motion sensor faucet	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM132-RM-MSLHW-B-FD (BLDG 2287-84)	Toddler 1 Motion sensor faucet	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM132-RM-MSLHW-FD (BLDG 2287-85)	Unisex Bathroom Motion sensor faucet	1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM113-MSLHW-FD (BLDG 2287-86)	Pre-toddler 2 Motion sensor faucet	0.79	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-2287-RM112-MSLHW-FD (BLDG 2287-87)	Pre-toddler 1 Motion sensor faucet	1.1	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions May 2018
 Naval Air Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb						Description	Recommended Level = 20ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 20ppb for sample collected on N/A are shown on the table.

Priority Areas Lead Testing and Corrective Actions May 2018
 Naval Air Station Mayport Child Development Center Building 2287

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/5/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb					
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	
Total Drinking	8	0	0	0	0	
Total Drinking > 20 ppb	0	0	0	0	0	
Total Cook/Brush	12	0	0	0	0	
Total Cook/Brush > 20 ppb	0	0	0	0	0	
Total Washing	66	0	0	0	0	
Total Washing > 20 ppb	0	0	0	0	0	
Total Samples	86	0	0	0	0	
Total Samples > 20 ppb	0	0	0	0	0	