

**U.S. NAVAL AIR STATION (NAS) SIGONELLA
2013 CONSUMER CONFIDENCE REPORT
MARINAI FAMILY HOUSING AREA**

About this report.

We are proud to present to you our annual drinking water quality report for calendar year 2013. This Consumer Confidence Report (CCR) provides valuable information on water quality and supports the Navy's commitment to providing high quality drinking water to our service members, their families, and DoD personnel. Presented in this report is information regarding the source of our drinking water, its constituents, and the health risks associated with those contaminants detected above applicable regulatory maximum contaminant levels (MCL) or action levels (AL).

What standards apply to drinking water overseas?

DoD water systems in Italy must comply with the Environmental Final Governing Standards-Italy (IFGS). The IFGS were developed through a comprehensive review of the U.S. Environmental Protection Agency (USEPA) Safe Drinking Water Act, generally applied Italian drinking water standards, and applicable international treaty provisions. When Italian and USEPA standards differ, the most protective requirement was adopted into the IFGS. This assures U.S. personnel, family members, and Italian employees receive drinking water which meets requirements mutually agreed upon by the U.S. and Italy. Additionally, This Consumer Confidence Report is prepared in accordance with CNIC Instructions 5090.1 and 5090.3, and COMNAVREGEUR Instruction 11330.1. The U.S. Food and Drug Administration establishes regulatory requirements for contaminants in bottled water, which must provide similar protection for public health.

Is my water safe to drink?

Yes. the tap water provided to the Marinai Family Housing Area in 2013 met the IFGS drinking water requirements for purchased water and the Preventive Medicine Authority has declared the water potable.

Annual Declaration of Potability

The Naval Air Station, Sigonella, Italy, (Marinai) drinking water is declared POTABLE. This declaration is based on the Annual Drinking Water Surveillance results conducted by US ARMY PUBLIC HEALTH COMMAND REGION – EUROPE for calendar year 2013, and current U.S. Naval Air Station, Sigonella, Italy, Public Works Department, Environmental Division water analysis and test results.

Johnfritz Antoine
LCDR, MSC, USN
Preventive Medicine/Environmental Health Officer
Preventive Medicine Department
U.S. Naval Hospital Sigonella, Italy

Where does my water come from?

The Marinai Housing facility purchases treated water from Pizzarotti & C., S.p.A. The water provided to the Marinai Housing facility is produced from two groundwater wells located outside the installation property. The water is treated using sand filters and reverse osmosis membrane filtration. The drinking water is disinfected prior to distribution.

Source water assessment and its availability.

The Navy completed a source water assessment in October 2011. This survey evaluated the adequacy of the drinking water sources, facilities, equipment, operation, and maintenance for producing and distributing safe drinking water. Additional information about the source water assessment is available from the Public Works Department (PWD) Environmental Office at 624-2722.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained from the USEPA Safe Drinking Water website, www.epa.gov/safewater/sdwa.

The source of your drinking water is groundwater produced at two wells. As water travels through the ground, it dissolves naturally occurring minerals (including radioactive material), and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water can include the following:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic compounds, such as salts and metals, can be naturally occurring or result from urban stormwater runoff, industrial, domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemicals, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive compounds can be naturally occurring or be the result of oil and gas production and mining activities.

Additional information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for thirty seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, please contact the Drinking Water Program Manager at 624-2722. Information on lead in drinking water and the steps you can take to minimize exposure is available from the Safe Drinking Water web site, www.epa.gov/safewater/sdwa.

Additional information for Nitrate.

If present, elevated levels of Nitrate can cause serious health problems. Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill. If you are concerned about bromate in your water, please contact PWD Environmental Office at 624-2722. Information on Nitrate in drinking water and the steps you can take to minimize exposure is available from the USEPA Safe Drinking Water website, www.epa.gov/safewater/sdwa.

Additional information for Bromate.

If present, elevated levels of bromate can cause serious health problems. Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer. If you are concerned about bromate in your water, please contact PWD Environmental Office at 624-2722. Information on bromate in drinking water and the steps you can take to minimize exposure is available from the USEPA Safe Drinking Water website, www.epa.gov/safewater/sdwa.

For what compounds is Marinai Housing drinking water tested?

Drinking water supplied to Marinai Housing Area is tested at least monthly and analyzed according to standards established by the IFGS. The water is analyzed for inorganic chemicals, volatile organic chemicals, pesticides, disinfection by-products, radionuclides, microbiological contaminants, and residual chlorine (residual disinfectant). Information on the specific compounds tested and the testing frequency is available from the PWD Environmental Office at 624-2722.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for

Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA Safe Drinking Water website, www.epa.gov/safewater/sdwa.

How can I get involved?

Customers should always observe water conservation practices. Water is a scarce resource in Sicily and everyone's cooperation in conserving water is greatly appreciated. If you have any questions, concerns, or ideas, please contact the PWD Environmental Office at 624-2722.

Water quality data table.

The following tables summarize the concentration of drinking water contaminants regulated by the IFGS that were detected during 2013, and compounds detected in previous years that are on a greater than one-year monitoring cycle. The presence of contaminants in the drinking water does not necessarily indicate that the water poses a health risk.

Contaminants (units)	USEPA MCLG or MRDLG	IFGS MCL	Your Water	Range		Year	Violation	Typical Source
				Low	High			
Disinfectants and Disinfection By-products								
Chlorine (as Cl ₂) (ppm)	4	NA	0.38	0.09	0.59	2013	No	Water additive used to control microbes.
TTHMs (total Trihalomethanes) (ppb)	Zero	30	11	ND	11	2013	No	By-product of drinking water disinfection
Bromate (ppm)	Zero	10	6.1	ND	8.09	2013	No	By-product of drinking water disinfection
Microorganism Contaminates								
Turbidity (NTU)	NA	--	0.09	0.07	0.12	2013	No	Turbidity is a measure of the cloudiness of water. It is used to indicate water quality and filtration effectiveness.
Inorganic Contaminants								
Nitrate [measured as Nitrogen Total] (ppm)	0.1	10	4.7	ND	4.7	2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Chloride (ppm)	1.0	250	210	ND	210	2013	No	Salt water intrusion of aquifer
Sulfate (ppm)	1.0	250	160	ND	160	2013	No	Salt water intrusion of aquifer
IFGS-Regulated Pesticides/Herbicides								
Aminomethylphosphonic acid (AMPA) (ppm)	No Std.	NA	.00019	ND	.00022	2013	No ⁽¹⁾	Chemical used in herbicides

(1) AMPA is a chemical used in the manufacture of Glyphosate. As per FGS regulations, and detectable levels of AMPA requires additional quarterly monitoring. Pesticide concentrations greater than the MDL of 0.00002 trigger increased monitoring

Contaminants	IFGS AL	90 th percentile	Sample Date	Samples Exceeding AL	Violation	Typical Source
Copper – AL at consumer taps (ppm)	1.3	0.011	FY13	0	No	Corrosion of household plumbing systems.
Lead – AL at consumer taps (ppb)	15	7	FY13	0	No	Corrosion of household plumbing systems.

Unit Descriptions	
Term	Definitions
NTU	Nephelometric Turbidity Unit – A unit for measuring turbidity. Turbidity is a measure of the cloudiness of the water.
ppb	Parts per billion, or micrograms per liter (µg/L).
ppm	Parts per million, or milligrams per liter (mg/L).
NA	Not Applicable.

Important Drinking Water Definitions	
Term	Definitions
AL	Action Level – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water. USEPA sets MCLs as close to the MCLG as feasible using the best available treatment technology. MCLs are set by the USEPA or Italian water standards, and the most conservative (typically the lowest) value is adopted by the IFGS.
MCLG	Maximum Contaminant Level Goal – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by USEPA, and include a margin of safety.
MRDLG	Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MDL	Method Detect Limit: The minimum concentration that can be measured and reported with 99% confidence that the concentration is greater than zero, but the exact concentration cannot be reliably quantified.

For more information, please contact the Installation Water Quality Board Environmental POC at 624-2725.