

LIPA Test Results PMRF CDC & YC

Sample Date: 11/25/19

Results Date: 12/12/19

Building #	Room Name	Category	Lead Results (ppb) <i>(EPA Limit is 15 ppb)</i>	Comments
1283 CDC	Baby Infant	Washing	Not Detected	
1283 CDC	Preschool Mauka	Washing	Not Detected	
1283 CDC	Preschool Makai	Washing	Not Detected	
1283 CDC	Infant - Adult	Washing	Not Detected	
1284 Pre-Toddler	Pre Toddler Mauka	Washing	Not Detected	
1284 Pre-Toddler	Pre Toddler Makai	Washing	Not Detected	
1284 Pre-Toddler	Toddler 1	Washing	Not Detected	
1284 Pre-Toddler	Toddler 2	Washing	Not Detected	
1318 Youth Center	Male Bathroom	Washing	Not Detected	
1318 Youth Center	Female Bathroom	Washing	Not Detected	
1318 Youth Center	Kitchen Sink	Cooking	Not Detected	