

**Priority Areas Lead Testing and Corrective Action**  
**Kinnick High School- Bldgs 3365 (Community Readiness Center 2nd Floor) 2020 Test Results**

**Table 1. Summary of Results**

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			POST REMEDIATION SAMPLING RESULTS		CORRECTIVE ACTIONS
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 15ppb					Description
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
<b>SAMPLING DATE</b>			3/25/2020			-	-	-	-	-	
<b>RESULTS DATE</b>			4/27/2020			-	-	-	-	-	
Drinking	YSK3365C001 (Rm 202)	Cooler	1.1	No	-	-	-	-	-	-	-
Drinking	YSK3365C002 (Rm 202)	Cooler	1.2	No	-	-	-	-	-	-	-
Washing	YSK3365F003 (Rm 201A)	Motion Sensor Faucet	1.2	No	-	-	-	-	-	-	-
Washing	YSK3365F004 (Rm 202B)	Motion Sensor Faucet	1.1	No	-	-	-	-	-	-	-
Cooking/Brushing	YSK3365F005 (Rm 214)	Faucet	1.1	No	-	-	-	-	-	-	-
Cooking/Brushing	YSK3365F007 (Rm 226)	Faucet	1.5	No	-	-	-	-	-	-	-
Drinking	YSK3365C008 (Rm 202)	Cooler	0.74	No	-	-	-	-	-	-	-
Drinking	YSK3365C009 (Rm 202)	Cooler	non-detect	No	-	-	-	-	-	-	-
Washing	YSK3365F010 (Rm 227)	Motion Sensor Faucet	2.5	No	-	-	-	-	-	-	-
Washing	YSK3365F011 (Rm 227)	Motion Sensor Faucet	1.3	No	-	-	-	-	-	-	-
Washing	YSK3365F012 (Rm 227)*	Motion Sensor Faucet	-	-	-	-	-	-	-	-	-
Washing	YSK3365F014 (Rm 228)*	Motion Sensor Faucet	-	-	-	-	-	-	-	-	-
Washing	YSK3365F015 (Rm 228)	Motion Sensor Faucet	1.6	No	-	-	-	-	-	-	-
Washing	YSK3365F016 (Rm 228)*	Motion Sensor Faucet	-	-	-	-	-	-	-	-	-
Drinking	YSK3365F018 (Rm 209)	Faucet	5.1	No	-	-	-	-	-	-	-

Notes :

\*Outlet was out of order and unable to collect samples. Samples will be collected upon completion of repair.

**Table 2. Summary Statistics**

CATEGORY	INITIAL SAMPLING RESULT	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS	
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>Total Drinking</b>	5	0	0	0	0	0
<b>Total Drinking &gt; 15 ppb</b>	0	0	0	0	0	0
<b>Total Cooking/Brushing</b>	2	0	0	0	0	0
<b>Total Cooking/Brushing &gt; 15 ppb</b>	0	0	0	0	0	0
<b>Total Washing</b>	5	0	0	0	0	0
<b>Total Washing &gt; 15 ppb</b>	0	0	0	0	0	0
<b>Total Samples</b>	12	0	0	0	0	0
<b>Total Samples &gt; 15 ppb</b>	0	0	0	0	0	0