



Contract No: N40084-15-D-0061

SGS Japan Test Report

Call No.17-586D

Sampling Location / Name:

Bldg 824 Ikego Elementary School

NAVFAC FE YOKOSUKA PRY4

Report Issue Date: 23 / Aug / 2017

SGS Japan Inc.

YBP North Square 1 3F
134 Godocho, Hodogaya-ku,
Yokohama, Kanagawa 240-0005
Tel: +81-045-330-1106
Fax: +81-045-330-1109

Signed by:

Tatsuya Abe
Business Line Manager
Environmental Services

DATA SUMMARY SHEET

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

RL: 0.00050 mg/L

Building Number / Floor: Bldg. 824 Ikego Elementary School Section C / 1st Floor

(1/1) Call No.17-586D

Room Name	Room #	Outlet Type	Sample ID#	Sampling			Results (mg/L)	Screening Level (mg/L)
				Date	Time	Collected by		
Kitchen	181	Faucet	IKE824F61-1F-R	4-Aug-17	8:35	Y. K.	0.0026	0.020
	181	Faucet	IKE824F61-2F-R	4-Aug-17	8:36	Y. K.	0.0010	0.020
	181	Faucet	IKE824F62-1F-R	4-Aug-17	8:37	Y. K.	0.0019	0.020
	181	Faucet	IKE824F62-2F-R	4-Aug-17	8:38	Y. K.	N.D.	0.020

Sampler's Names: Y. Kanazawa

None of the results in the summary above exceeded Screening Threshold Level.

[Notes]

RL: Reporting Limit

N.D.: Analyte Not Detected and if present below RL reported

Screening Threshold Level: 20ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L); Reference: CNIC Ser.

N45/14U132588 dated 8 February2014 "Sampling and Testing for Lead in Drinking Water In Priority Areas"

TABLE OF CONTENTS

ANALYSIS REPORT SGS Accutest	4
CHAIN OF CUSTODY RECORD.....	15
CUSTOMER REQUEST.....	23
FLOOR PLAN.....	25
MEASUREMENT CERTIFICATION BUSINESS REGISTRATION CERTIFICATE.....	27