

**Priority Areas Lead Testing and Corrective Action
Yokosuka Teen Center - Bldg. 1257 (2018 Test Results)**

Table 1. Summary of Results

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			Recommended Level = 20ppb								
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			7/25/2018			-	-	-		-	-
RESULTS DATE			9/4/2018			-	-	-		-	-
Drinking	YSK1257C001	Cooler	non-detect	No	-	-	-	-	-	-	-
Washing	YSK1257F002	Faucet	2.5	No	-	-	-	-	-	-	-
Washing	YSK1257F003	Faucet	2.7	No	-	-	-	-	-	-	-
Washing	YSK1257F004	Faucet (Hose bibb)	7.4	No	-	-	-	-	-	-	-
Washing	YSK1257F005	Portable Sink	1.5	No	-	-	-	-	-	-	-

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS	
	Recommended Level = 20ppb					
	First Draw (ppb)	Water Fountain Follow up	First Draw (ppb)	Follow up Flush - Collected 30	First Draw (ppb)	Follow up Flush - Collected 30
Total Drinking	1	0	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0	0
Total Cooking/Brushing	0	0	0	0	0	0
Total Cooking/Brushing > 20 ppb	0	0	0	0	0	0
Total Washing	4	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0	0
Total Samples	5	0	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0	0