

**Priority Areas Lead Testing and Corrective Action
Yokosuka Main Child Development Center - Bldg. 4300 (2018 Test Results)**

Table 1. Summary of Results

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb			Description	Recommended Level = 20ppb	
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			7/21/2018			-	-	-		-	-
RESULTS DATE			9/4/2018			-	-	-		-	-
Drinking	YSK4300C001	Cooler	0.6	NO	-	-	-	-		-	-
Drinking	YSK4300C002	Cooler	non-detect	NO	-	-	-	-		-	-
Washing	YSK4300F004	Faucet	2.3	NO	-	-	-	-		-	-
Drinking	YSK4300C005	Cooler	0.57	NO	-	-	-	-		-	-
Washing	YSK4300F006	Faucet	0.61	NO	-	-	-	-		-	-
Washing	YSK4300F007	Faucet	2.3	NO	-	-	-	-		-	-
Washing	YSK4300F008	Faucet	1.2	NO	-	-	-	-		-	-
Washing	YSK4300F009	Faucet	1.5	NO	-	-	-	-		-	-
Washing	YSK4300F010	Faucet	0.85	NO	-	-	-	-		-	-
Drinking	YSK4300C011	Cooler	0.71	NO	-	-	-	-		-	-
Washing	YSK4300F012	Faucet	1.3	NO	-	-	-	-		-	-
Washing	YSK4300F013	Faucet	non-detect	NO	-	-	-	-		-	-
Washing	YSK4300F014	Faucet	1.1	NO	-	-	-	-		-	-
Washing	YSK4300F015	Faucet	0.97	NO	-	-	-	-		-	-
Washing	YSK4300F016	Faucet	0.69	NO	-	-	-	-		-	-
Washing	YSK4300F017	Faucet	1.7	NO	-	-	-	-		-	-
Washing	YSK4300F018	Faucet	1.4	NO	-	-	-	-		-	-
Washing	YSK4300F019	Faucet	10	NO	-	-	-	-		-	-
Washing	YSK4300F020	Faucet	6.2	NO	-	-	-	-		-	-
Washing	YSK4300F021	Faucet	1.5	NO	-	-	-	-		-	-
Washing	YSK4300F022	Faucet	0.71	NO	-	-	-	-		-	-
Washing	YSK4300F023	Faucet	0.97	NO	-	-	-	-		-	-
Washing	YSK4300F024	Faucet	1.8	NO	-	-	-	-		-	-
Drinking	YSK4300C025	Cooler	11	NO	-	-	-	-		-	-
Washing	YSK4300F026	Faucet	2.6	NO	-	-	-	-		-	-
Washing	YSK4300F027	Faucet	2	NO	-	-	-	-		-	-
Washing	YSK4300F028	Faucet	4.2	NO	-	-	-	-		-	-
Washing	YSK4300F029	Faucet	1.4	NO	-	-	-	-		-	-
Washing	YSK4300F030	Faucet	1.4	NO	-	-	-	-		-	-
Drinking	YSK4300C031	Cooler	3.3	NO	-	-	-	-		-	-
Washing	YSK4300F032	Faucet	1.3	NO	-	-	-	-		-	-
Washing	YSK4300F033	Faucet	1.8	NO	-	-	-	-		-	-
Washing	YSK4300F034	Faucet	0.83	NO	-	-	-	-		-	-
Washing	YSK4300F035	Faucet	0.61	NO	-	-	-	-		-	-
Washing	YSK4300F036	Faucet	2	NO	-	-	-	-		-	-
Washing	YSK4300F037	Faucet	2.1	NO	-	-	-	-		-	-
Drinking	YSK4300C038	Cooler	0.67	NO	-	-	-	-		-	-
Washing	YSK4300F039	Faucet	1.5	NO	-	-	-	-		-	-
Washing	YSK4300F040	Faucet	0.52	NO	-	-	-	-		-	-
Washing	YSK4300F041	Faucet	1.1	NO	-	-	-	-		-	-
Washing	YSK4300F042	Faucet	1	NO	-	-	-	-		-	-
Washing	YSK4300F043	Faucet	0.84	NO	-	-	-	-		-	-
Washing	YSK4300F044	Faucet	0.68	NO	-	-	-	-		-	-
Washing	YSK4300F045	Faucet	6.7	NO	-	-	-	-		-	-

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb			Description	Recommended Level = 20ppb	
						Water Fountain 15 min. Follow up Flush Sample Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
Washing	YSK4300F046	Faucet	1.8	NO	-	-	-	-	-	-	-
Cooking/Brushing	YSK4300F047	Faucet	19	NO	-	-	-	-	-	-	-
Washing	YSK4300F048	Faucet	4.8	NO	-	-	-	-	-	-	-
Washing	YSK4300F049	Faucet	3.2	NO	-	-	-	-	-	-	-
Washing	YSK4300F050	Faucet	2.4	NO	-	-	-	-	-	-	-
Washing	YSK4300F051	Faucet	9.2	NO	-	-	-	-	-	-	-
Cooking/Brushing	YSK4300F052	Faucet	non-detect	NO	-	-	-	-	-	-	-
Washing	YSK4300F053	Faucet	1.4	NO	-	-	-	-	-	-	-
Washing	YSK4300F054	Faucet	4.2	NO	-	-	-	-	-	-	-
Washing	YSK4300F055	Faucet	2.4	NO	-	-	-	-	-	-	-
Cooking/Brushing	YSK4300F057	Faucet	non-detect	NO	-	-	-	-	-	-	-
Cooking/Brushing	YSK4300F058	Faucet	3.4	NO	-	-	-	-	-	-	-
Washing	YSK4300F059	Faucet	3	NO	-	-	-	-	-	-	-
Drinking	YSK4300B060	Bubbler	15	NO	-	-	-	-	-	-	-
Drinking	YSK4300B061	Bubbler	13	NO	-	-	-	-	-	-	-
Drinking	YSK4300B062	Bubbler	3.2	NO	-	-	-	-	-	-	-
Drinking	YSK4300B063	Bubbler	2.3	NO	-	-	-	-	-	-	-
Cooking/Brushing	YSK4300F073	Faucet	0.9	NO	-	-	-	-	-	-	-
Washing	YSK4300F074	Faucet	0.84	NO	-	-	-	-	-	-	-
Washing	YSK4300F075	Faucet	7.3	NO	-	-	-	-	-	-	-
Washing	YSK4300F076	Faucet	1.7	NO	-	-	-	-	-	-	-
Washing	YSK4300F077	Faucet	2.7	NO	-	-	-	-	-	-	-
Washing	YSK4300F078	Faucet	0.97	NO	-	-	-	-	-	-	-
Washing	YSK4300F079	Faucet	3.1	NO	-	-	-	-	-	-	-
Washing	YSK4300F080	Faucet	0.97	NO	-	-	-	-	-	-	-
Washing	YSK4300F081	Faucet	1	NO	-	-	-	-	-	-	-
Washing	YSK4300F082	Faucet	2.3	NO	-	-	-	-	-	-	-
Drinking	YSK4300C083	Cooler	14	NO	-	-	-	-	-	-	-
Washing	YSK4300F084	Faucet	1.4	NO	-	-	-	-	-	-	-
Washing	YSK4300F085	Faucet	1.9	NO	-	-	-	-	-	-	-
Drinking	YSK4300C086	Cooler	0.5	NO	-	-	-	-	-	-	-
Washing	YSK4300F087	Faucet	0.67	NO	-	-	-	-	-	-	-
Washing	YSK4300F088	Faucet	0.86	NO	-	-	-	-	-	-	-
Washing	YSK4300F089	Faucet	0.78	NO	-	-	-	-	-	-	-
Washing	YSK4300F090	Faucet	1.2	NO	-	-	-	-	-	-	-
Washing	YSK4300F091	Faucet	3.5	NO	-	-	-	-	-	-	-
Washing	YSK4300F092	Faucet	1.8	NO	-	-	-	-	-	-	-
Washing	YSK4300F093	Faucet	1.3	NO	-	-	-	-	-	-	-
Washing	YSK4300F094	Faucet	1.3	NO	-	-	-	-	-	-	-
Washing	YSK4300F095	Faucet	1.9	NO	-	-	-	-	-	-	-
Washing	YSK4300F096	Faucet	3.8	NO	-	-	-	-	-	-	-
Washing	YSK4300F097	Faucet	2.3	NO	-	-	-	-	-	-	-
Washing	YSK4300F098	Faucet	1.9	NO	-	-	-	-	-	-	-
Drinking	YSK4300C099	Cooler	3	NO	-	-	-	-	-	-	-
Washing	YSK4300F100	Faucet	3.1	NO	-	-	-	-	-	-	-
Washing	YSK4300F101	Faucet	non-detect	NO	-	-	-	-	-	-	-

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)	Description	Recommended Level = 20ppb	
										First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
Washing	YSK4300F102	Faucet	0.94	NO	-	-	-	-	-	-	-
Cooking/Brushing	YSK4300F103	Faucet	1.3	NO	-	-	-	-	-	-	-

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS	
	Recommended Level = 20ppb					
	First Draw (ppb)	Water Fountain Follow up	First Draw (ppb)	Follow up Flush - Collected 30	First Draw (ppb)	Follow up Flush - Collected 30
Total Drinking	14	0	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0	0
Total Cooking/Brushing	6	0	0	0	0	0
Total Cooking/Brushing > 20 ppb	0	0	0	0	0	0
Total Washing	72	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0	0
Total Samples	92	0	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0	0