

**Priority Areas Lead Testing and Corrective Action
Yokosuka School Age Care/ Kinnick High School - Bldg H12 (2019 Test Results)**

Table 1. Summary of Results

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 15ppb			Description	Recommended Level = 15ppb	
						Water Fountain 15 min. Follow up Flush Sample Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			2/15/2019			-	-	-		-	-
RESULTS DATE			3/26/2019			-	-	-		-	-
Washing	YSKH12F001	Faucet	3.3	No	-	-	-	-	-	-	-
Washing	YSKH12F002	Faucet	7.3	No	-	-	-	-	-	-	-
Washing	YSKH12F003	Faucet	1.4	No	-	-	-	-	-	-	-
Washing	YSKH12F004	Faucet	2	No	-	-	-	-	-	-	-
Drinking	YSKH12C005	Cooler	Non-detect	No	-	-	-	-	-	-	-
Washing	YSKH12F006	Faucet	1.5	No	-	-	-	-	-	-	-
Cooking/Brushing	YSKH12F007	Faucet	4.1	No	-	-	-	-	-	-	-

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS	
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
Total Drinking	1	0	0	0	0	0
Total Drinking > 15 ppb	0	0	0	0	0	0
Total Cooking/Brushing	1	0	0	0	0	0
Total Cooking/Brushing > 15 ppb	0	0	0	0	0	0
Total Washing	5	0	0	0	0	0
Total Washing > 15 ppb	0	0	0	0	0	0
Total Samples	7	0	0	0	0	0
Total Samples > 15 ppb	0	0	0	0	0	0