

**Priority Areas Lead Testing and Corrective Action
Yokosuka School Age Care- Bldg. H20 (2018 Test Results)**

Table 1. Summary of Results

SAMPLE LOCATION DESCRIPTION			INITIAL FULL BUILDING SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			7/31/2018			-	-	-		-	-
RESULTS DATE			9/12/2018			-	-	-		-	-
Washing	YSKH20F001	Faucet (Portable sink)	non-detect	NO	-	-	-	-	-	-	-
Washing	YSKH20F002	Faucet (Portable sink)	non-detect	NO	-	-	-	-	-	-	-
Drinking	YSKH20C003	Cooler	non-detect	NO	-	-	-	-	-	-	-
Drinking	YSKH20C004	Cooler	non-detect	NO	-	-	-	-	-	-	-
Washing	YSKH20F005	Faucet	1.9	NO	-	-	-	-	-	-	-
Washing	YSKH20F006	Faucet	2.7	NO	-	-	-	-	-	-	-
Washing	YSKH20F007	Faucet	1.2	NO	-	-	-	-	-	-	-
Washing	YSKH20F008	Faucet	3	NO	-	-	-	-	-	-	-
Washing	YSKH20F009	Faucet	1.9	NO	-	-	-	-	-	-	-
Washing	YSKH20F010	Faucet	1.6	NO	-	-	-	-	-	-	-
Washing	YSKH20F011	Faucet	2	NO	-	-	-	-	-	-	-
Washing	YSKH20F012	Faucet	3.2	NO	-	-	-	-	-	-	-
Washing	YSKH20F013	Faucet	2.9	NO	-	-	-	-	-	-	-
Washing	YSKH20F014	Faucet (Portable sink)	non-detect	NO	-	-	-	-	-	-	-
Washing	YSKH20F015	Faucet (Portable sink)	non-detect	NO	-	-	-	-	-	-	-
Washing	YSKH20F016	Faucet (Janitor's closet)	2.6	NO	-	-	-	-	-	-	-

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS		POST REMEDIATION RESULTS	
	Recommended Level = 20ppb					
	First Draw (ppb)	Water Fountain Follow up	First Draw (ppb)	Follow up Flush - Collected 30	First Draw (ppb)	Follow up Flush - Collected 30
Total Drinking	2	0	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0	0
Total Cooking/Brushing	0	0	0	0	0	0
Total Cooking/Brushing > 20 ppb	0	0	0	0	0	0
Total Washing	14	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0	0
Total Samples	16	0	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0	0