

Priority Areas Lead Testing and Corrective Actions (December 2014)  
School Age Care Facility (Building 1297)

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS				RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb			Description		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		mm/dd/yyyy		
SAMPLING DATE			12/2/2014			mm/dd/yyyy	12/11/2014	12/11/2014			mm/dd/yyyy	
RESULTS DATE			12/8/2014			mm/dd/yyyy	12/16/2014	12/16/2014			mm/dd/yyyy	
DRINKING	NP-B1297-CAFÉ-HHW-FD	Café (right faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
DRINKING	NP-B1297-HALL-TCWF8-FD	Teen Center Water Fountain	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
COOKING	NP-B1297-TCK-K-FD	Teen Center Kitchen	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-CAFÉ-LHW-FD	Café (left faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-BATH-HHW-FD	Staff Restroom	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-ARTRM-HHW(A)-FD	Art Room (left faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-ARTRM0HHW(B)-FD	Art Room (right faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-SCIRM-HHW-FD	Science Area	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	BP-B1297-UT-LAUNDRM-HHW-FD	Laundry Room	3	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-UT-JANRM-HHW-FD	Janitor Closet	3	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-BBATH-LHW(A)-FD	Boy's Bathroom (left faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-BBATH-LHW(B)-FD	Boy's Bathroom (right faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	BNP-B1297-GBATH-LHW(A)-FD	Girl's Bathroom (left faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-GBATH-LHW(B)-FD	Girl's Bathroom (right faucet)	2	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-TCRM-HHW-FD	Teen Center Meeting Room	21	YES	12/8/2014	N/A	16	2	Follow on sampling and testing of this site was under 20 ppb for both the first draw and flush sample after the aerator was cleaned. The faucet was also replaced with a lead free fixture. The new fixture will be retested 6 months after installation.	N/A	N/A	
HAND WASHING	NP-B1297-TCGBATH-LHW(A)-FD	Teen Center Girl's Bathroom (left faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-TCGBATH-LHW(B)-FD	Teen Center Girl's Bathroom (right faucet)	2	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-TCBBATH-LHW(A)-FD	Teen Center Boy's Bathroom (left faucet)	non-detect	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-TCBBATH-LHW(B)-FD	Teen Center Boy's Bathroom (right faucet)	1	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	
HAND WASHING	NP-B1297-TCUT-HHW-FD	Teen Center Janitor Closet	6	NO	N/A	N/A	N/A	N/A	Aerators Replaced in July 2014 and will undergo regular preventative cleaning.	N/A	N/A	

Priority Areas Lead Testing and Corrective Actions (December 2014)  
 School Age Care Facility (Building 1297)

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS		POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Recommended Level = 20ppb	
				Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	2	N/A	0	0	0
Total Drinking > 20 ppb	0	N/A	0	0	0
Total Cooking/Brushing Teeth	1	N/A	0	0	0
Total Cooking/Brush Teeth > 20 ppb	0	N/A	0	0	0
Total Hand Washing	17	N/A	1	1	0
Total Hand Washing > 20 ppb	1	N/A	0	0	0
Total Samples	20	N/A	1	1	0
Total Samples > 20 ppb	1	N/A	0	0	0