

**NSA HAMPTON ROADS PORTSMOUTH ANNEX  
LEAD AND COPPER INDIVIDUAL RESULTS  
(MAY 2017)**

No.	Date	Sampling Site	Normal Stagnation Period (hours)	Lead (ppb)	Copper (ppb)
1	May 24, 2017	1	15:00	^Non-detect	322
2	May 24, 2017	2	15:50	^Non-detect	243
3	May 24, 2017	3	15:45	^Non-detect	201
4	May 24, 2017	20	13:00	^Non-detect	99
5	May 24, 2017	104	14:21	^Non-detect	102
6	May 24, 2017	107	6:00	^Non-detect	126
7	May 24, 2017	247	7:05	^Non-detect	227
8	May 24, 2017	*249 CWC	13:25	^Non-detect	73
9	May 24, 2017	*249 Offices	12:30	^Non-detect	197
10	May 24, 2017	250	14:00	^Non-detect	51
11	May 24, 2017	252	10:43	^Non-detect	79
12	May 24, 2017	*256 NEX	11:32	^Non-detect	188
13	May 24, 2017	*256 Liberty Center	13:10	^Non-detect	148
14	May 24, 2017	267	12:00	^Non-detect	307
15	May 24, 2017	271	14:40	^Non-detect	50
16	May 24, 2017	272	10:05	^Non-detect	134
17	May 24, 2017	273	10:00	^Non-detect	97
18	May 24, 2017	274	17:30	^Non-detect	90 <sup>th</sup> Percentile= 252
19	May 24, 2017	276	8:42	^Non-detect	100
20	May 24, 2017	277	13:00	^Non-detect	108
21	May 24, 2017	287	12:28	^Non-detect	201
22	May 24, 2017	288	7:30	^Non-detect	114
23	May 24, 2017	289	20:30	^Non-detect	86
24	May 25, 2017	2	15:30	^Non-detect	250
25	May 25, 2017	3	16:00	^Non-detect	183
26	May 25, 2017	20	13:00	^Non-detect	162
27	May 25, 2017	104	14:32	^Non-detect	119
28	May 25, 2017	107	6:20	^Non-detect	80
29	May 25, 2017	247	7:10	6	334
30	May 25, 2017	*249 CWC	10:05	2	556
31	May 25, 2017	*249 Offices	14:30	^Non-detect	193
32	May 25, 2017	250	14:00	^Non-detect	63
33	May 25, 2017	*256 NEX	11:15	^Non-detect	86
34	May 25, 2017	*256 Liberty Center	13:10	^Non-detect	145
35	May 25, 2017	272	10:10	^Non-detect	124
36	May 25, 2017	273	10:00	^Non-detect	130
37	May 25, 2017	274	17:15	4	164
38	May 25, 2017	276	8:40	^Non-detect	87
39	May 25, 2017	287	15:27	^Non-detect	206
40	May 25, 2017	288	9:00	^Non-detect	107

ppb = parts per billion  
Lead Action Level = 15 ppb based on the 90<sup>th</sup> percentile value  
Copper Action Level = 1300 ppb based on the 90<sup>th</sup> percentile value  
\*These are segregated buildings.  
^The 90<sup>th</sup> Percentile for the lead samples are the Non-detect results.