

**CRANEY ISLAND
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2016)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	140	5 th highest result = 3	5 th highest result = 465
2	288 - 2nd Floor	4 th highest result = 2	82
3	82	1	4 th highest result = 134
4	288 - 1st Floor	Non-detect	80
5	294	Non-detect	127

Compliance Calculation – Average 4th and 5th highest sample results

- **90th Percentile Lead Level = 2.5 ppb**
- **90th Percentile Copper Level = 299.5 ppb**

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value