

**JEB LITTLE CREEK WATERWORKS
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2016)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	3604	5	799
2	3364	4	655
3	3870	90 th Percentile = 3	263
4	CB301	3	54
5	3821	2	68
6	3820	2	64
7	3814	2	227
8	Navy Bldg 4172 (5006 Gela)	2	90
9	Navy Bldg 4157 (5094 Gela Drive)	2	169
10	3872	1	92
11	Navy Bldg 4053 (2215 Casablanca Rd)	1	38
12	Navy Bldg 4075 (4911 Safi Circle)	1	67
13	Navy Bldg 4027 (4943 Juno Road)	1	34
14	3816	Non-detect	93
15	CB310	Non-detect	261
16	1602	Non-detect	264
17	3603	Non-detect	254
18	3812	Non-detect	91
19	1265	Non-detect	90 th Percentile = 284
20	Navy Bldg 4102 (2212 Sword)	Non-detect	44

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value

The 90th Percentile for the lead samples is 3 ppb.