

**NALF FENTRESS WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
July – December 2019	10 ppb – passed	1020 ppb - passed
July – December 2018	2 ppb – passed	275 ppb - passed
January – June 2018	13 ppb – passed	1,030 ppb - passed
July – December 2017	11 ppb – passed	519 ppb - passed
June – September 2015	3 ppb - passed	529 ppb - passed
June – September 2012	10 ppb - passed	674 ppb - passed
June – September 2009	6 ppb - passed	525 ppb - passed
June – September 2006	4 ppb - passed	400 ppb - passed
June – September 2005	6 ppb - passed	500 ppb - passed
June – September 2004	4.1 ppb - passed	406.5 ppb - passed
January - June 2003	4 ppb - passed	656 ppb - passed

ppb = parts per billion