

**NAS OCEANA WATERWORKS
LEAD AND COPPER INDIVIDUAL RESULTS
(July – December 2021)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	B. 321	Non-detect	66
2	B.330	90 th Percentile - 1	90 th Percentile - 102
3	B.333	Non-detect	90
4	B.536	Non-detect	180
5	B 1105	Non-detect	190
6	978 F Avenue	Non-detect	72
7	983 F Avenue	Non-detect	77
8	984 F Avenue	Non-detect	39
9	986 F Avenue	Non-detect	37
10	1004 F Avenue	Non-detect	65
11	1016 F Avenue	1	65
12	1021 F Avenue	Non-detect	54
13	1038 F Avenue	Non-detect	60
14	1041 F Avenue	Non-detect	69
15	1061 F Avenue	2	85
16	1789 F Avenue	Non-detect	22
17	1793 F Avenue	Non-detect	60
18	1797 F Avenue	Non-detect	49
19	1804 F Avenue	1	81
20	1807 F Avenue	Non-detect	55

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

*The 90th Percentile for the lead samples are the Non-detect results.

Copper Action Level = 1300 ppb based on the 90th percentile value