

NSA Crane				
Lead and Copper Individual Results				
June - September 2017				
No.	Installation	Sampling Site	Lead (ppb)	Copper (ppb)
2	NSA Crane	3059	8	22
9	NSA Crane	3284	4	183
4	NSA Crane	3308	90th Percentile = 3	16
13	NSA Crane	122	2	11
7	NSA Crane	3325	<1	277
3	NSA Crane	2805	<1	90th Percentile = 61
16	NSA Crane	3173	<1	60
12	NSA Crane	3319	<1	58
19	NSA Crane	3291	<1	33
1	NSA Crane	3422	<1	24
20	NSA Crane	3318	<1	21
17	NSA Crane	2713 West	<1	14
8	NSA Crane	2074	<1	10
5	NSA Crane	127	<1	8
10	NSA Crane	Quarters B	<1	4
11	NSA Crane	56	<1	4
14	NSA Crane	3245	<1	2
15	NSA Crane	198	<1	1
18	NSA Crane	2708	<1	1
6	NSA Crane	77	<1	<1

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value