

**NAVAL STATION GREAT LAKES  
LEAD AND COPPER INDIVIDUAL RESULTS  
(September 2017)**

No.	Installation	Sampling Site	Lead (ppb)	Copper (ppb)
1	NSGL	LP1A041	6.1	45
2	NSGL	LP1A007	2.1	90th percentile = 87
3	NSGL	LA1A029	2.0	41
4	NSGL	LP1A035	90th percentile = 1.5	52
5	NSGL	LP1A016	1.5	45
6	NSGL	LA1A018	1.1	55
7	NSGL	LA1A001	1.1	32
8	NSGL	LP1A004	Non-detect	360
9	NSGL	LA1A005	Non-detect	190
10	NSGL	LP1A028	Non-detect	160
11	NSGL	LP1A009	Non-detect	77
12	NSGL	LP1A003	Non-detect	70
13	NSGL	LP1A034	Non-detect	63
14	NSGL	LP1A038	Non-detect	48
15	NSGL	LP1A040	Non-detect	43
16	NSGL	LP1A008	Non-detect	39
17	NSGL	LP1A026	Non-detect	35
18	NSGL	LP1A027	Non-detect	33
19	NSGL	LP1A032	Non-detect	33
20	NSGL	LP1A030	Non-detect	31
21	NSGL	LP1A039	Non-detect	26
22	NSGL	LP1A044	Non-detect	25
23	NSGL	LP1A037	Non-detect	24
24	NSGL	LP1A010	Non-detect	19
25	NSGL	LP1A045	Non-detect	3.7
26	NSGL	LP1A006	Non-detect	3.6
27	NSGL	LP1A043	Non-detect	3.0
28	NSGL	LP1A002	Non-detect	Non-detect
29	NSGL	LP1A015	Non-detect	Non-detect
30	NSGL	LP1A046	Non-detect	Non-detect

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90<sup>th</sup> percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value