

**NAVAL WEAPONS STATION EARLE
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
July, 2016	<1 ppb - Passed	90 ppb - Passed
July, 2013	<1 ppb - Passed	200 ppb - Passed
July, 2012	<1 ppb - Passed	60 ppb - Passed
July, 2010	1 ppb - Passed	100 ppb - Passed
July, 2009	7 ppb - Passed	100 ppb - Passed
July, 2008	1 ppb - Passed	20 ppb - Passed
July, 2007	<1 ppb - Passed	400 ppb - Passed

ppb = parts per billion