

NAVAL WEAPONS STATION YORKTOWN, CHEATHAM ANNEX WATERWORKS HISTORICAL LEAD AND COPPER RESULTS		
Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90th Percentile (Action Level: 1300 ppb)
June – September 2016	7 ppb – Passed	463 ppb - Passed
June – September 2013	4 ppb- Passed	700 ppb - Passed
June – September 2012	5 ppb - Passed	491 ppb - Passed
June – September 2011	4 ppb - Passed	912 ppb - Passed
January – June 2011	9.8 ppb - Passed	1130 ppb - Passed
June – September 2010	29.5 ppb - Failed	2180 ppb - Passed
June – September 2007	8 ppb – Passed	475 ppb - Passed

ppb = parts per billion