

**NAVAL STATION NEWPORT
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
June – September 2017	40 ppb - Failed	130 ppb - Passed
June – September 2014	10 ppb - Passed	120 ppb - Passed
June – September 2011	4 ppb - Passed	80 ppb - Passed

ppb = parts per billion