

**NORFOLK NAVAL SHIPYARD WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
June – September 2015	1 ppb - Passed	200 ppb - Passed
July – December 2012	2 ppb - Passed	253 - Passed
*June – September 2009	5 ppb - Passed	233 - Passed
June – September 2005	2 ppb – Passed	91 ppb - Passed

ppb = parts per billion

*The triennial samples due in the June – September 2008 monitoring period were inadvertently collected in October 2008 and were not considered compliance samples.