

**NORTHWEST ANNEX WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
June – September 2017	1 ppb – Passed	507 ppb - Passed
June – September 2014	2 ppb - Passed	408 ppb - Passed
June – September 2011	2 ppb - Passed	431 ppb - Passed
June – September 2008	5 ppb - Passed	576 ppb - Passed
June – September 2005	2 ppb - Passed	400 ppb - Passed

ppb = parts per billion