

**NORFOLK NAVAL SHIPYARD
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2015)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	1461	3	248
2	174	2	174
3	278	1	188
4	706	90 th Percentile = 1	51
5	1510	1	149
6	9	Non-detect	72
7	14	Non-detect	40
8	15	Non-detect	299
9	16	Non-detect	133
10	31	Non-detect	197
11	33	Non-detect	121
12	59	Non-detect	88
13	171	Non-detect	71
14	184	Non-detect	108
15	234	Non-detect	89
16	235	Non-detect	63
17	274	Non-detect	84
18	277	Non-detect	250
19	310	Non-detect	48
20	510	Non-detect	178
21	701	Non-detect	34
22	702	Non-detect	111
23	705	Non-detect	28
24	1484	Non-detect	59
225	1487	Non-detect	90 th Percentile = 198
26	1499	Non-detect	13
27	1500	Non-detect	81
28	1502	Non-detect	32
29	1503	Non-detect	26
30	1505	Non-detect	120

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value

The 90th Percentile for the lead samples is 1 ppb.