

**ST. JULIENS CREEK ANNEX WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

| Monitoring Period | Lead 90th Percentile (Action Level: 15 ppb) | Copper 90 th Percentile (Action Level: 1300 ppb) |
|------------------------|--|--|
| July – September 2015 | 2 ppb - Passed | 22 ppb - Passed |
| June – September 2012 | 2 ppb - Passed | 190 ppb – Passed |
| *June – September 2009 | 3 ppb – Passed | 276 ppb - Passed |
| June – September 2005 | 2 ppb - Passed | 91 ppb - Passed |

ppb = parts per billion

*The triennial samples due in the June – September 2008 monitoring period were inadvertently collected in October 2008 and were not considered compliance samples.