

**NAVAL WEAPONS STATION YORKTOWN (NWSY)  
WATERWORKS  
LEAD AND COPPER INDIVIDUAL RESULTS  
(June - September 2016)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	1951A	3	42
2	1920C	90 <sup>th</sup> Percentile = 2	50
3	1931D	1	90 <sup>th</sup> Percentile = 57
4	1915C	1	38
5	1917A	Non-detect	26
6	1921B	Non-detect	68
7	1922C	Non-detect	54
8	1927A	Non-detect	16
9	1948A	Non-detect	46
10	1950C	Non-detect	34

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90<sup>th</sup> percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value