

Priority Areas Lead Testing and Corrective Actions November 2014
NAS CORPUS CHRISTI Play Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description							Description		
			SAMPLING DATE			11/20/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy
RESULTS DATE			12/3/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
DRINKING	CC-PLAY-ALPHA-WFBCOMB-FD (OPA-3)	Softball Field Alpha - Water fountain portion of combo.	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	CC-PLAY-BRAVO-WFCOMB-FD (OPA-5)	Softball Field Bravo - Water fountain portion of combo.	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	CC-PLAY-E AND DIMMIT-WFB-FD (OPA-7)	Softball Field on corner of E St. and Dimmit St. - Water fountain.	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-ALPHA-HOSE-FD (OPA-2)	Softball Field Alpha - Hose Bib	3.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-ALPHA-HOSECOMB-FD (OPA-4)	Softball Field Alpha - Hose bib portion of combo.	5.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-BRAVO-HOSECOMB-FD (OPA-6)	Softball Field Bravo - Hose bib portion of combo.	4.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-E AND DIMMIT-HOSEA-FD (OPA-8)	Softball Field on corner of E St. and Dimmit St. - Spigot outside of fence near third base	3.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-E AND DIMMIT-HOSEB-FD (OPA-9)	Softball Field on corner of E St. and Dimmit St. - Spigot outside of fence near center field	14	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-E AND DIMMIT-HOSEC-FD (OPA-10)	Softball Field on corner of E St. and Dimmit St. - Spigot outside of fence near right field	11	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-E AND DIMMIT-HOSED-FD (OPA-11)	Softball Field on corner of E St. and Dimmit St. - Spigot outside of fence near first base	6.2	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Priority Areas Lead Testing and Corrective Actions November 2014
NAS CORPUS CHRISTI Play Areas

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	3	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	7	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	10	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0