

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NCBC GULFPORT Teen Center
 Building 335A

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Description	Recommended Level = 20ppb
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/4/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/15/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	GPT-335A-RM06-HALL-WFC-A-FD (BLDG-335A-12)	Cooler fountain in Teen Center	9.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GPT-335A-RM06-HALL-WFC-b-FD (BLDG-335A-13)	Cooler fountain in Teen Center	12	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 20ppb for sample collected on N/A are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS						POST REMEDIATION RESULTS
	Recommended Level = 20ppb							
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	
Total Drinking	2	0	0	0	0	0	0	
Total Drinking > 20 ppb	0	0	0	0	0	0	0	
Total Cook/Brush	0	0	0	0	0	0	0	
Total Cook/Brush > 20 ppb	0	0	0	0	0	0	0	
Total Washing	0	0	0	0	0	0	0	
Total Washing > 20 ppb	0	0	0	0	0	0	0	
Total Samples	2	0	0	0	0	0	0	
Total Samples > 20 ppb	0	0	0	0	0	0	0	