

Priority Areas Lead Testing and Corrective Actions (OCT 2014)  
NCBC GULFPORT  
Outdoor Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	Description	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/5/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/15/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	GPT-230-PLAY-WFC-FD (OPA-2)	Cooler Fountain between restrooms at Seabee Lake	9.1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Notes:

<sup>1</sup> Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

<sup>2</sup> Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 20ppb for sample collected on N/A are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	1	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	1	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0