

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
 NASJRB FORT WORTH Youth Center
 Building 1145

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 20ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)							Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		
SAMPLING DATE			10/15/2014			mm/dd/yyyy	11/8/2014	11/8/2014		11/24/2014	
RESULTS DATE			10/27/2014			mm/dd/yyyy	11/13/2014	11/13/2014		12/3/2014	
COOKING	FW-1145-K-KA-FD(BLDG 1145-1)	Side by side kitchen faucet Faucet	3.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	FW-1145-K-KB-FD(BLDG 1145-2)	Side by side kitchen faucet Faucet	3.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	FW-1145-BATH-GIRLS-HHW-FD(BLDG 1145-4)	Girls bathroom Note: Boys bathroom has automatic sensor faucet	1.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	FW-1145-RM-HHW-FD(BLDG 1145-5)	Single handwash sink in general play area	36	YES	11/13/2014	N/A	37	7.8	Corrective Action Required - Fixture Replacement	6.5	2

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb. Aerator cleaning conducted and re-sampling was conducted on 11/08/2014.

² Post-remediation sampling was initially conducted on 11/24/2014. Corrective action was fixture replacement. Final results for sample collected on 11/24/2014 are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Recommended Level = 20ppb			First Draw (ppb)
		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	0	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	2	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	2	0	1	1	1
Total Washing > 20 ppb	1	0	1	0	0
Total Samples	4	0	1	1	1
Total Samples > 20 ppb	1	0	1	0	0