

Priority Areas Lead Testing and Corrective Actions December 2014  
NS Guantanamo Bay Youth Center Building 2148

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 20ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)							Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		
<b>SAMPLING DATE</b>			<b>12/7/2014</b>			<b>mm/dd/yyyy</b>	<b>1/11/2015</b>	<b>1/11/2015</b>		<b>mm/dd/yyyy</b>	
<b>RESULTS DATE</b>			<b>12/17/2014</b>			<b>mm/dd/yyyy</b>	<b>1/16/2015</b>	<b>1/16/2015</b>		<b>mm/dd/yyyy</b>	
DRINKING	GTMO-2148-HALL-WFC-FD (BLDG 2148-8)	Fountain by Bathrooms - Cooler Fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2148-RM113-GYM-WFC-FD (BLDG 2148-9)	Fountain in Gym - Cooler Fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	GTMO-2148-K-K-FD (BLDG 2148-10)	Kitchen - Kitchen Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM125-RM-HHW-FD (BLDG 2148-1)	Art Room - High handwash sink	2.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM116-BATH-BOYS-HHWA-FD (BLDG 2148-2)	Boys Bathroom - High handwash sink	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM116-BATH-BOYS-HHWB-FD (BLDG 2148-3)	Boys Bathroom - High handwash sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM116-BATH-BOYS-HHWC-FD (BLDG 2148-4)	Boys Bathroom - High handwash sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM118-BATH-GIRLS-HHWA-FD (BLDG 2148-5)	Girls Bathroom - High handwash sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM118-BATH-GIRLS-HHWB-FD (BLDG 2148-6)	Girls Bathroom - High handwash sink	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-RM118-BATH-GIRLS-HHWC-FD (BLDG 2148-7)	Girls Bathroom - High handwash sink	2.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-HOSEA-FD (BLDG 2148-11)	Hose outlet in rear of building - Hose attachment	6.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-HOSEB-FD (BLDG 2148-12)	Hose outlet on playground side of building - Hose attachment	11	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2148-HOSEC-FD (BLDG 2148-13)	Hose outlet on parking lot side of building on left (facing building) - Hose attachment	34	YES	N/A	N/A	3.5	non-detect	Routine Control Measures Only	N/A	N/A

Priority Areas Lead Testing and Corrective Actions December 2014  
NS Guantanamo Bay Youth Center Building 2148

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			12/7/2014			mm/dd/yyyy	1/11/2015	1/11/2015			
<b>RESULTS DATE</b>			12/17/2014			mm/dd/yyyy	1/16/2015	1/16/2015			
WASHING	GTMO-2148-HOSED-FD (BLDG 2148-14)	Hose outlet on parking lot side of building on right (facing building) - Hose attachment	8.6	NO	N/A	N/A	N/A	N/A	N/A	N/A	

Notes:  
<sup>1</sup> Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	2	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	11	0	1	1	0
Total Washing > 20 ppb	1	0	0	0	0
Total Samples	14	0	1	1	0
Total Samples > 20 ppb	1	0	0	0	0