

Priority Areas Lead Testing and Corrective Actions November 2014
NAS KINGSVILLE Youth Center Building 2742

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/18/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/24/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	KVL-2742-RM-WFC-FD (BLDG 2742-1)	Fountain between restrooms - Water Fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KVL-2742-K-K-FD (BLDG 2742-6)	Kitchen - Kitchen sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KVL-2742-BATH-W-HHWA-FD (BLDG 2742-2)	Women's bathroom - Sink in women's restroom, left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KVL-2742-BATH-W-HHWB-FD (BLDG 2742-3)	Women's bathroom - Sink in women's restroom, right	1.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KVL-2742-BATH-M-HHWA-FD (BLDG 2742-4)	Men's bathroom - Sink in men's restroom	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KVL-2742-BATH-UNISEX-HHW-FD (BLDG 2742-5)	Restroom in kitchen area - Sink in unisex restroom	2.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KVL-2742-HOSE-FD (BLDG 2742-7)	Hose spigot outside side entrance to play area - Hose bib	6	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	1	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	5	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	7	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0