

Priority Areas Lead Testing and Corrective Actions November 2014  
NAS MERIDIAN Child Development Center Building 256

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/13/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/21/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	MER-256-HALL-WFCA-FD (BLDG 256-8)	Water Fountain Across Room 131 Left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-HALL-WFCB-FD (BLDG 256-9)	Water Fountain Across Room 131 Right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-RM124-RM-HWCOMB-FD (BLDG 256-19)	Toddler Room Combo, sink	3.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-RM124-RM-WFCOMB-FD (BLDG 256-20)	Toddler Room Combo, water fountain	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-RM120-RM-WFCOMB-FD (BLDG 256-25)	Pre-School Room Combo, Water Fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-RM120-RM-HWCOMB-FD (BLDG 256-26)	Pre-School Room Combo, Sink	1.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-RM120-PLAY-WFB-FD (BLDG 256-27)	Outside Water Fountain By Back Entrance To Room 120	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-256-RM127-PLAY-WFB-FD (BLDG 256-28)	Outside Water Fountain By Back Entrance To Room 127 (Outdoor Storage Room)	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MER-256-RM119-K-KA-FD (BLDG 256-30)	Kitchen Sink Side By Side Left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MER-256-RM119-K-KB-FD (BLDG 256-31)	Kitchen Sink Side By Side Right	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM103-BATH-UNISEX-HHW-FD (BLDG 256-1)	Restroom By Main Entrance Restroom Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM135-RM-HHWA-FD (BLDG 256-2)	Infant Room High Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM135-RM-LHW-FD (BLDG 256-3)	Infant Room Low Handwash Sink	6.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM135-RM-HHWB-FD (BLDG 256-4)	Infant Room Step Lever Activated Faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM131-RM-HHWA-FD (BLDG 256-5)	Pre-Toddler Room High Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM131-RM-LHW-FD (BLDG 256-6)	Pre-Toddler Room Low Handwash Sink	12	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions November 2014  
 NAS MERIDIAN Child Development Center Building 256

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/13/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/21/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	MER-256-RM131-RM-HHWP-FD (BLDG 256-7)	Pre-Toddler Room Step Lever Activated Faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM110-LOUNGE-K-FD (BLDG 256-10)	Staff Break Room Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-BATH-UNISEX-HHW-FD (BLDG 256-11)	Staff Bathroom Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM128-RM-HHWA-FD (BLDG 256-12)	Pre-Toddler Room High Handwash Sink	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM128-RM-LHWA-FD (BLDG 256-13)	Pre-Toddler Room Low Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM128-RM-HHWP-FD (BLDG 256-14)	Pre-Toddler Room - Step Lever Activated Faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM124-RM-HHWA-FD (BLDG 256-15)	Toddler Room High Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM124-RM-LHWA-FD (BLDG 256-16)	Toddler Room Low Handwash Sink, Left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM124-RM-LHWP-FD (BLDG 256-17)	Toddler Room Low Handwash Sink, Right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM124-RM-HHWP-FD (BLDG 256-18)	Toddler Room - Step Lever Activated Faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM120-RM-HHWA-FD (BLDG 256-21)	Pre-School Room High Handwash Sink	2.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM120-RM-LHWA-FD (BLDG 256-22)	Pre-School Room Low Hand Wash Sink	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM120-RM-LHWP-FD (BLDG 256-23)	Pre-School Room Low Hand Wash Sink	4.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM120-RM-HHWP-FD (BLDG 256-24)	Pre-School Room Step Lever Activated Faucet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM119-K-HHWA-FD (BLDG 256-29)	High Handwash Kitchen Sink Immediately By Entrance	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM119-K-HHWP-FD (BLDG 256-32)	High Hand Wash Kitchen Sink Under Pots/Pans	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM119-K-HHWC-FD (BLDG 256-33)	High Hand Wash Kitchen Sink By General Storage Room 138	2.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MER-256-RM119-K-KC-FD (BLDG 256-34)	Kitchen Sink In Back Of Room	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Priority Areas Lead Testing and Corrective Actions November 2014  
 NAS MERIDIAN Child Development Center Building 256

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	8	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	2	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	24	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	34	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0