

Priority Areas Lead Testing and Corrective Actions November 2014  
NAS MERIDIAN Play Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			11/13/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
<b>RESULTS DATE</b>			11/21/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
DRINKING	MER-PLAY-BERNATH-WFBA-FD (OPA-1)	Bernath Baseball Field Fountain by restrooms (not functioning)	1.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-PLAY-BERNATH-WFBB-FD (OPA-2)	Bernath Baseball Field Water Fountain	12	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-PLAY-BASKETBALL-WFCOMB-FD (OPA-3)	Basketball Courts Combination water fountain/hose bib.	2.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-PLAY-BASKETBALL-HOSECOMB-FD (OPA-4)	Basketball Courts Combination water fountain/hose bib.	20	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-369-PLAY-WFB-FD (OPA-5)	Fountain outside gym by ball field Not functioning	2.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MER-369-PLAY-WFT (OPA-6)		14	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	6	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	6	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0