

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
NAS PENSACOLA Youth Center Building 3690

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?		Recommended Level = 20ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
SAMPLING DATE			10/18/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/28/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	PNS-3690-HALL-WFC-FD (BLDG 3690-1)	Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNS-3690-GYM-WFC-A-FD (BLDG 3690-9)	Gym First Wfc On Left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNS-3690-GYM-WFC-B-FD (BLDG 3690-10)	Gym Wfc On Right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	PNS-3690-K-K-A-FD (BLDG 3690-11)	Kitchen	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	PNS-3690-K-K-B-FD (BLDG 3690-12)	Kitchen	4	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	PNS-3690-K-ICE-FD (BLDG 3690-13)	Kitchen	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	PNS-3690-K-WFC-FD (BLDG 3690-14)	Snack Area Outside Of Kitchen	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-GBATH-HHW-A-FD (BLDG 3690-2)	Girls Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-GBATH-HHW-B-FD (BLDG 3690-3)	Girls Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-GBATH-HHW-C-FD (BLDG 3690-4)	Girls Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-BBATH-HHW-A-FD (BLDG 3690-5)	Boys Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-BBATH-HHW-B-FD (BLDG 3690-6)	Boys Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-BBATH-HHW-C-FD (BLDG 3690-7)	Boys Outside Of Office	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PNS-3690-RM-HHW-FD (BLDG 3690-8)	Project Activity Rm Art Room	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
 NAS PENSACOLA Youth Center Building 3690

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	3	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	4	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	7	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	14	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0