

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
 NAS PENSACOLA Outdoor Play Area - MWR Sports Complex
 Building 4116

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			10/19/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/3/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	PNSCS-4116-PLAY-WFB-A-FD (BLDG 4116-1)	Ball Field C near home plate	3.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNSCS-4116-PLAY-WFB-B-FD (BLDG 4116-2)	Ball Field D near first base	2.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNSCS-4116-PLAY-WFB-C-FD (BLDG 4116-3)	Ball Field D near home plate	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNSCS-4116-PLAY-WFB-D-FD (BLDG 4116-4)	Ball Field B near home plate	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNSCS-4116-PLAY-WFB-E-FD (BLDG 4116-5)	Ball Field A near play area	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNSCS-4116-PLAY-WFB-F-FD (BLDG 4116-6)	Soccer Field by play area	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PNSCS-4116-PLAY-WFB-G-FD (BLDG 4116-7)	Soccer Field away from play area near trees	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	7	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	7	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0