

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
NAS PENSACOLA Child Development Center Annex Building 4120

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			Recommended Level = 20ppb			Recommended Level = 20ppb				Recommended Level = 20ppb	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			10/18/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/29/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	PNSCS-4120-RM8-STOR-ICE-FD (BLDG 4120-1)	1st Room On Right Icemaker In Storage Room	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-RM2-RM-WFB-FD (BLDG 4120-3)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-RM4-RM-WFB-FD (BLDG 4120-12)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-RM6-RM-WFB-FD (BLDG 4120-15)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-RM5-RM-WFB-FD (BLDG 4120-24)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-RM3-RM-WFB-FD (BLDG 4120-27)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-RM1-RM-WFB-FD (BLDG 4120-33)	Used As Lounge; 2 Lhw & Hhw Not Accessable	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-HALL-WFC-A-FD (BLDG 4120-35)	Water Fountains In Hall	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PNSCS-4120-HALL-WFC-B-FD (BLDG 4120-36)	Water Fountains In Hall	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PNSCS-4120-RM1-RM-K-FD (BLDG 4120-34)	Used As Lounge; 2 Lhw & Hhw Not Accessable	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PNSCS-4120-RM7-LOUNGE-K-FD (BLDG 4120-38)	Teachers Lounge	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM2-RM-HHW-A-FD (BLDG 4120-2)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM2-RM-HHW-B-FD (BLDG 4120-4)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM2-RM-LHW-A-FD (BLDG 4120-5)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM2-RM-LHW-B-FD (BLDG 4120-6)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM2-RM-LHW-C-FD (BLDG 4120-7)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM4-RM-LHW-A-FD (BLDG 4120-8)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM4-RM-LHW-B-FD (BLDG 4120-9)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM4-RM-LHW-C-FD (BLDG 4120-10)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
NAS PENSACOLA Child Development Center Annex Building 4120

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			10/18/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			
RESULTS DATE			10/29/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			
WASHING	PNSCS-4120-RM4-RM-HHW-A-FD (BLDG 4120-11)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM4-RM-HHW-B-FD (BLDG 4120-13)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM6-RM-HHW-A-FD (BLDG 4120-14)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM6-RM-HHW-B-FD (BLDG 4120-16)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM6-RM-LHW-A-FD (BLDG 4120-17)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM6-RM-LHW-B-FD (BLDG 4120-18)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM6-RM-LHW-C-FD (BLDG 4120-19)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM5-RM-LHW-A-FD (BLDG 4120-20)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM5-RM-LHW-B-FD (BLDG 4120-21)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM5-RM-LHW-C-FD (BLDG 4120-22)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM5-RM-HHW-A-FD (BLDG 4120-23)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM5-RM-HHW-B-FD (BLDG 4120-25)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM3-RM-HHW-A-FD (BLDG 4120-26)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM3-RM-HHW-B-FD (BLDG 4120-28)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM3-RM-LHW-A-FD (BLDG 4120-29)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM3-RM-LHW-C-FD (BLDG 4120-31)		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM1-RM-LHW-A-FD (BLDG 4120-32)	Used As Lounge; 1 Lhw Hot Only & Hhw Not Accessible	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM9-BATH-HHW-FD (BLDG 4120-37)	Bathroom Sink	non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PNSCS-4120-RM1-RM-LHW-B-FD (BLDG 4120-39)	Used As Lounge; 1 Lhw Hot Only & Hhw Not Accessible	2.4	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
 NAS PENSACOLA Child Development Center Annex Building 4120

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	9	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	2	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	27	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	38	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0