

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NAS JACKSONVILLE Child Development Center
 Building 2070

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb			Recommended Level = 20ppb				Description	Recommended Level = 20ppb
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/23/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	JAX-2070-HALL-WFCA-FD (BLDG 2070-1)	Cooler Fountain between restrooms in lobby	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-HALL-WFCB-FD (BLDG 2070-2)	Cooler Fountain between restrooms in lobby	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM130-RM-WFCOMB-FD (BLDG 2070-33)	Pre-school 1 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM132-RM-WFCOMB-FD (BLDG 2070-37)	Pre-school 2 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM134-RM-WFCOMB-FD (BLDG 2070-41)	Pre-school 3 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM136-RM-WFCOMB-FD (BLDG 2070-45)	Pre-school 4 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM138-RM-WFCOMB-FD (BLDG 2070-49)	Pre-school 5 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM142-RM-WFCOMB-FD (BLDG 2070-58)	Toddler 5 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM144-RM-WFCOMB-FD (BLDG 2070-62)	Toddler 4 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM146-RM-WFCOMB-FD (BLDG 2070-66)	Toddler 3 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM148-RM-WFCOMB-FD (BLDG 2070-70)	Toddler 2 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM150-RM-WFCOMB-FD (BLDG 2070-74)	Toddler 1 - Lowered bubbler fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM129-LOUNGE-K-FD (BLDG 2070-29)	Teacher's lounge/breakroom - Sink for food prep/dish washing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NAS JACKSONVILLE Child Development Center
 Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	Description	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/23/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
COOKING	JAX-2070-RM141-K-HHWA-FD (BLDG 2070-50)	Kitchen sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM141-K-KA-FD (BLDG 2070-52)	Kitchen preparation sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM141-K-HHWC-FD (BLDG 2070-53)	Kitchen hand wash sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM141-K-KB-FD (BLDG 2070-54)	Kitchen preparation sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM110-RM-HHWA-FD (BLDG 2070-3)	Infant 4 - Faucet with foot activated step lever	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM110-RM-HHWB-FD (BLDG 2070-4)	Infant 4 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM112-RM-HHWA-FD (BLDG 2070-5)	Infant 5 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM112-RM-HHWB-FD (BLDG 2070-6)	Infant 5 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM114-RM-HHWA-FD (BLDG 2070-7)	Infant 6 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM114-RM-HHWB-FD (BLDG 2070-8)	Infant 6 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM116-RM-HHWA-FD (BLDG 2070-9)	Infant 7 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM116-RM-HHWB-FD (BLDG 2070-10)	Infant 7 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM118-RM-HHWA-FD (BLDG 2070-11)	Pre-Toddler 6 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM118-RM-HHWB-FD (BLDG 2070-12)	Pre-Toddler 6 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM120-RM-HHWA-FD (BLDG 2070-13)	Pre-Toddler 5 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM120-RM-HHWB-FD (BLDG 2070-14)	Pre-Toddler 5 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM122-RM-HHWA-FD (BLDG 2070-15)	Pre-Toddler 4 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM122-RM-HHWB-FD (BLDG 2070-16)	Pre-Toddler 4 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NAS JACKSONVILLE Child Development Center
 Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			Recommended Level = 20ppb							Recommended Level = 20ppb	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	Description	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/23/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	JAX-2070-RM157-RM-HHWA-FD (BLDG 2070-17)	Pre-Toddler 3 - Faucet with foot activated step lever	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM157-RM-HHWA-FD (BLDG 2070-18)	Pre-Toddler 3 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM159-RM-HHWA-FD (BLDG 2070-19)	Pre-Toddler 2 - Faucet with foot activated step lever	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM159-RM-HHWA-FD (BLDG 2070-20)	Pre-Toddler 2 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM161-RM-HHWA-FD (BLDG 2070-21)	Pre-Toddler 1 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM161-RM-HHWA-FD (BLDG 2070-22)	Pre-Toddler 1 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM163-RM-HHWA-FD (BLDG 2070-23)	Infant 1 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM163-RM-HHWA-FD (BLDG 2070-24)	Infant 1 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM165-RM-HHWA-FD (BLDG 2070-25)	Infant 2 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM165-RM-HHWA-FD (BLDG 2070-26)	Infant 2 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM167-RM-HHWA-FD (BLDG 2070-27)	Infant 3 - Faucet with foot activated step lever	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM167-RM-HHWA-FD (BLDG 2070-28)	Infant 3 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-HHWA-FD (BLDG 2070-30)	Pre-school 1 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-HHWA-FD (BLDG 2070-31)	Pre-school 1 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-HWCOMB-FD (BLDG 2070-32)	Pre-school 1 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-HHWA-FD (BLDG 2070-34)	Pre-school 2 - Faucet with foot activated step lever	1.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-HHWA-FD (BLDG 2070-35)	Pre-school 2 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-HWCOMB-FD (BLDG 2070-36)	Pre-school 2 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NAS JACKSONVILLE Child Development Center
 Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Description	Recommended Level = 20ppb
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy
RESULTS DATE			10/23/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy
WASHING	JAX-2070-RM134-RM-HHWA-FD (BLDG 2070-38)	Pre-school 3 - Faucet with foot activated step lever	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM134-RM-HHWB-FD (BLDG 2070-39)	Pre-school 3 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM134-RM-HWCOMB-FD (BLDG 2070-40)	Pre-school 3 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM136-RM-HHWA-FD (BLDG 2070-42)	Pre-school 4 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM136-RM-HHWB-FD (BLDG 2070-43)	Pre-school 4 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM136-RM-HWCOMB-FD (BLDG 2070-44)	Pre-school 4 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM138-RM-HHWA-FD (BLDG 2070-46)	Pre-school 5 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM138-RM-HHWB-FD (BLDG 2070-47)	Pre-school 5 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NAS JACKSONVILLE Child Development Center
 Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/23/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	JAX-2070-RM138-RM-HWCOMB-FD (BLDG 2070-48)	Pre-school 5 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM141-K-HHWB-FD (BLDG 2070-51)	Kitchen hand wash sink	9.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM142-RM-HHWA-FD (BLDG 2070-55)	Toddler 5 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM142-RM-HHWB-FD (BLDG 2070-56)	Toddler 5 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM142-RM-HWCOMB-FD (BLDG 2070-57)	Toddler 5 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM144-RM-HHWA-FD (BLDG 2070-59)	Toddler 4 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM144-RM-HHWB-FD (BLDG 2070-60)	Toddler 4 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM144-RM-HWCOMB-FD (BLDG 2070-61)	Toddler 4 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM146-RM-HHWA-FD (BLDG 2070-63)	Toddler 3 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM146-RM-HHWB-FD (BLDG 2070-64)	Toddler 3 - Faucet with regular hand lever	3.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM146-RM-HWCOMB-FD (BLDG 2070-65)	Toddler 3 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM148-RM-HHWA-FD (BLDG 2070-67)	Toddler 2 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM148-RM-HHWB-FD (BLDG 2070-68)	Toddler 2 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM148-RM-HWCOMB-FD (BLDG 2070-69)	Toddler 2 - Lowered hand wash	2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM150-RM-HHWA-FD (BLDG 2070-71)	Toddler 1 - Faucet with foot activated step lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM150-RM-HHWB-FD (BLDG 2070-72)	Toddler 1 - Faucet with regular hand lever	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NAS JACKSONVILLE Child Development Center
 Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	Description	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			
RESULTS DATE			10/23/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			
WASHING	JAX-2070-RM150-RM-HWCOMB-FD (BLDG 2070-73)	Toddler 1 - Lowered hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 20ppb for sample collected on N/A are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	12	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	5	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	57	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	74	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0