

Priority Areas Lead Testing and Corrective Actions October 2014
NASJRB New Orleans Youth Center SAC and Teen Center Building 561

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description		
SAMPLING DATE RESULTS DATE			10/29/2014				mm/dd/yyyy	11/20/2014	11/20/2014		
			11/5/2014				mm/dd/yyyy	11/21/2014	11/21/2014		
DRINKING	NOLA-561-RM106-HALL-WFCA-FD (BLDG 561-3)	Fountain beside snack bar - Drinking fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	NOLA-561-RM106-HALL-WFCB-FD (BLDG 561-4)	Fountain beside snack bar - Drinking fountain	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	NOLA-561-RM110-HALL-WFCA-FD (BLDG 561-14)	Fountain across Girls' Bathroom - Water Fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	NOLA-561-RM110-HALL-WFCB-FD (BLDG 561-15)	Fountain across Girls' Bathroom - Water Fountain	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	NOLA-561-RM104-K-K-FD (BLDG 561-1)	Snack Bar - Food prep Sink	44	YES	11/18/2014	N/A	2.8	4.3	Routine Control Measures Only - Aerator Cleaning	N/A	N/A
COOKING	NOLA-561-RM104-K-ICE-FD (BLDG 561-2)	Snack Bar - Ice Machine	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	NOLA-561-RM113-LOUNGE-K-FD (BLDG 561-7)	Teacher's lounge/breakroom - Kitchen sink in lounge/breakroom	8.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	NOLA-561-RM121-RM-K-FD (BLDG 561-16)	Activity Room 1 (Orange room) - Food prep Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	NOLA-561-RM121-RM-K-FD (BLDG 561-17)	Activity Room 3 (Blue Room) - Food prep Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	NOLA-561-RM121-RM-K-FD (BLDG 561-18)	Activity Room 4 (Purple room) - Food prep Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	NOLA-561-RM121-RM-K-FD (BLDG 561-19)	Activity Room 2 (Green room) - Food prep Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM108-BATH-HHW-FD (BLDG 561-5)	Bathroom sink - Unisex bathroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM107-BATH-HHW-FD (BLDG 561-6)	Bathroom sink - Unisex bathroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM117-BATH-HHWA-FD (BLDG 561-8)	Boys' Bathroom - Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM117-BATH-HHWA-FD (BLDG 561-9)	Boys' Bathroom - Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM117-BATH-HHWC-FD (BLDG 561-10)	Boys' Bathroom - Handwash Sink	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM118-BATH-HHWA-FD (BLDG 561-11)	Girls' Bathroom - Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions October 2014
NASJRB New Orleans Youth Center SAC and Teen Center Building 561

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			10/29/2014			mm/dd/yyyy	11/20/2014	11/20/2014		mm/dd/yyyy	
RESULTS DATE			11/5/2014			mm/dd/yyyy	11/21/2014	11/21/2014		mm/dd/yyyy	
WASHING	NOLA-561-RM118-BATH-HHWB-FD (BLDG 561-12)	Girls' Bathroom - Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	NOLA-561-RM118-BATH-HHWC-FD (BLDG 561-13)	Girls' Bathroom - Handwash Sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

² Additional routine control measures such as aerator cleaning were implemented and final results below recommended level of 20ppb for sample collected on 20 NOV 2014 are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Recommended Level = 20ppb			First Draw (ppb)
		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	4	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	7	0	1	1	0
Total Cook/Brush > 20 ppb	1	0	0	0	0
Total Washing	8	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	19	0	1	1	0
Total Samples > 20 ppb	1	0	0	0	0