

Priority Areas Lead Testing and Corrective Actions October 2014
NASJRB New Orleans Play Areas Building 571 and 39

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS			
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?		Recommended Level = 20ppb			First Draw (ppb)
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
SAMPLING DATE			10/29/2014			mm/dd/yyyy	mm/dd/yy	mm/dd/yyyy				mm/dd/yyyy	
RESULTS DATE			11/4/2014			mm/dd/yyyy	mm/dd/yy	mm/dd/yyyy				mm/dd/yyyy	
DRINKING	NOLA-571-PLAY-WFBA-FD (OPA 39&571-1)	Covered Pavillion in Sports Complex (571) - Bubbler fountain situated higher	1.5	NO	N/A	N/A	N/A	N/A				N/A	N/A
DRINKING	NOLA-571-PLAY-WFBB-FD (OPA 39&571-2)	Covered Pavillion in Sports Complex (571) - Bubbler fountain situated lower	1.7	NO	N/A	N/A	N/A	N/A				N/A	N/A
DRINKING	NOLA-571-WFC-A-FD (OPA 39&571-3)	Fountain outside restroom building in Sports Complex (571) - Cooler fountain	3.1	NO	N/A	N/A	N/A	N/A				N/A	N/A
DRINKING	NOLA-571-WFC-B-FD (OPA 39&571-4)	Fountain outside restroom building in Sports Complex (571) - Cooler fountain	2.7	NO	N/A	N/A	N/A	N/A				N/A	N/A
COOKING	NOLA-39-K-FD (OPA 39&571- 5)	Plaquedilla Park Restroom Bldg (39) - Steel sink outside restroom building	2	NO	N/A	N/A	N/A	N/A				N/A	N/A

Notes:

Priority Areas Lead Testing and Corrective Actions October 2014
 NASJRB New Orleans Play Areas Building 571 and 39

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	4	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	5	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0