

Priority Areas Lead Testing and Corrective Actions November 2014  
NSB KINGS BAY Child Development Center Building 150

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?		Recommended Level = 20ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
<b>SAMPLING DATE</b>			<b>11/1/2014</b>			<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>			<b>mm/dd/yyyy</b>
<b>RESULTS DATE</b>			<b>11/10/2014</b>			<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>			<b>mm/dd/yyyy</b>
DRINKING	KB-150-RM133-RM-WFCOMB-FD (BLDG 150-7)	Pre-Toddler 4 Combo, water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-150-HALL-WFC-FD (BLDG 150-23)	Water fountain adjacent to 113 - Water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-150-PLAY-WFBB-FD (BLDG 150-26)	Outside Play Area Outside water fountain	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM144-RM-HHWA-FD (BLDG 150-1)	Pre-Toddler 3 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM144-RM-HHWB-FD (BLDG 150-2)	Pre-Toddler 3 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM144-RM-HWCOMB-FD (BLDG 150-4)	Pre-Toddler 3 Combo, sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM133-RM-HHWA-FD (BLDG 150-5)	Pre-Toddler 4 High hand wash	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM133-RM-HHWB-FD (BLDG 150-6)	Pre-Toddler 4 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM133-RM-HWCOMB-FD (BLDG 150-8)	Pre-Toddler 4 Combo, sink	1.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM133-RM-HHWC-FD (BLDG 150-9)	Pre-Toddler 4 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM144-RM-HHWC-FD (BLDG 150-10)	Pre-Toddler 3 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM117-RM-HHWA-FD (BLDG 150-11)	Pre-Toddler 1 High hand wash	14	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM117-RM-HHWB-FD (BLDG 150-12)	Pre-Toddler 1 High hand wash	7.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM117-RM-LHWA-FD (BLDG 150-13)	Pre-Toddler 1 Children's Restroom	2.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM117-RM-LHWB-FD (BLDG 150-14)	Pre-Toddler 1 Children's Restroom	2.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM128-RM-HHWA-FD (BLDG 150-15)	Pre-Toddler 2 High hand wash	1.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM128-RM-HHWB-FD (BLDG 150-16)	Pre-Toddler 2 High hand wash	2.4	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions November 2014  
NSB KINGS BAY Child Development Center Building 150

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			<b>11/1/2014</b>			<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>		<b>mm/dd/yyyy</b>	
<b>RESULTS DATE</b>			<b>11/10/2014</b>			<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>	<b>mm/dd/yyyy</b>		<b>mm/dd/yyyy</b>	
WASHING	KB-150-RM128-RM-LHWA-FD (BLDG 150-17)	Pre-Toddler 2 Children's Restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM128-RM-LHWB-FD (BLDG 150-18)	Pre-Toddler 2 Children's Restroom	2.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM113-RM-HHW-FD (BLDG 150-20)	High hand wash	2.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM106-BATH-UNISEX-HHW-FD (BLDG 150-24)	Unisex bathroom Unisex bathroom sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-150-RM107-BATH-UNISEX-HHW-FD (BLDG 150-25)	Unisex bathroom Unisex bathroom sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Recommended Level = 20ppb			First Draw (ppb)
		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	3	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	19	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	22	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0