

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Child Development Center Buildings 152

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	KB-152-HALL-WFC-FD (BLDG 152-1)	Fountain by entrance/lobby	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM152-RM-WFCOMBA-FD (BLDG 152-3)	Pre-K Room E Combo, water fountain on left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM152-RM-WFCOMBB-FD (BLDG 152-5)	Pre-K Room E Combo, water fountain on right	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM152-RM-WFC-FD (BLDG 152-6)	Fountain by rear entrance Outside water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM137-RM-WFCOMBA-FD (BLDG 152-8)	Pre-K2 Room D Combo, water fountain on left	1.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM137-RM-WFCOMBB-FD (BLDG 152-10)	Pre-K2 Room D Combo, water fountain on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM157-RM-WFCOMB-FD (BLDG 152-18)	Infant Room 4 Combo, water fountain	2.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM150-RM-WFCOMBA-FD (BLDG 152-20)	Pre-K 1, room F Combo, water fountain on left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM150-RM-WFCOMBB-FD (BLDG 152-22)	Pre-K 1, room F Combo, water fountain on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM160-RM-WFB-FD (BLDG 152-27)	Fountain outside back entrance Outside water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-152-RM164-RM-WFCOMB-FD (BLDG 152-31)	Infant Room 1 Combo, water fountain	3.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-152-RM125-K-HHW-FD (BLDG 152-36)	Kitchen sink	6	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-152-RM125-K-KA-FD (BLDG 152-37)	Double kitchen sink on left	2.5	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Child Development Center Buildings 152

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
COOKING	KB-152-RM125-K-KB-FD (BLDG 152-38)	Double kitchen sink on right	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM152-RM-HWCOMBA-FD (BLDG 152-2)	Pre-K Room E Combo, high hand wash on left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM152-RM-HWCOMBB-FD (BLDG 152-4)	Pre-K Room E Combo, high hand wash on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM137-RM-HWCOMBA-FD (BLDG 152-7)	Pre-K2 Room D Combo, high hand wash on left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM137-RM-HWCOMBB-FD (BLDG 152-9)	Pre-K2 Room D Combo, high hand wash on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM160-RM-HHWA-FD (BLDG 152-11)	Infant Room 3 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM160-RM-HHWB-FD (BLDG 152-12)	Infant Room 3 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM160-RM-HWCOMB-FD (BLDG 152-13)	Infant Room 3 Combo, high hand wash	1.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM157-RM-HHWA-FD (BLDG 152-15)	Infant Room 4 High hand wash	2.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM157-RM-HHWB-FD (BLDG 152-16)	Infant Room 4 High hand wash	4.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM157-RM-HWCOMB-FD (BLDG 152-17)	Infant Room 4 Combo, high hand wash	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM150-RM-HWCOMBA-FD (BLDG 152-19)	Pre-K 1, room F Combo, high hand wash on left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM150-RM-HWCOMBB-FD (BLDG 152-21)	Pre-K 1, room F Combo, high hand wash on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM161-RM-HHWA-FD (BLDG 152-23)	Infant Room 2 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Child Development Center Buildings 152

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	KB-152-RM161-RM-HHWP-FD (BLDG 152-24)	Infant Room 2 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM161-RM-HWCMB-FD (BLDG 152-25)	Infant Room 2 Combo, high hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM164-RM-HHWA-FD (BLDG 152-28)	Infant Room 1 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM164-RM-HHWP-FD (BLDG 152-29)	Infant Room 1 High hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-RM164-RM-HWCMB-FD (BLDG 152-30)	Infant Room 1 Combo, high hand wash	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-BATH-HHWA-FD (BLDG 152-32)	Unisex restroom by entrance sink	3.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-152-BATH-HHWP-FD (BLDG 152-33)	Unisex restroom by supply room sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	11	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	3	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	20	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	34	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0