

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Youth Center Buildings 166

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	KB-166-HALL-WFCA-FD (BLDG 166-1)	Fountain by entrance across Room 129 - High fountain on left	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-166-HALL-WFCB-FD (BLDG 166-2)	Fountain by entrance across Room 129 - Low fountain on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-166-PLAY-WFC-FD (BLDG 166-12)	Outside by covered playground - Outside water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-166-K-HHW-FD (BLDG 166-14)	Handwash sink. - Handwash sink in kitchen	2.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-166-K-KA-FD (BLDG 166-15)	Sink with emergency eyewash faucet. - Sink in kitchen with eyewash	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-166-K-KB-FD (BLDG 166-16)	Kitchen sink for food prep. - Sink in kitchen for food prep.	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-166-K-ICE-FD (BLDG 166-17)	Ice Machine. - Ice Machine in Kitchen	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	KB-166-K-KC-FD (BLDG 166-18)	Food prep area where oven/range is located. - Kitchen food prep sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM119-BATH-M-HHWA-FD (BLDG 166-3)	Bathroom designated for children under 12 - Sink on left in boys restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM119-BATH-M-HHWB-FD (BLDG 166-4)	Bathroom designated for children under 12 - Sink in middle in boys restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM119-BATH-M-HHWC-FD (BLDG 166-5)	Bathroom designated for children under 12 - Sink on right in boys restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-BATH-UNISEX-HHW-FD (BLDG 166-6)	Bathroom designated for Adults - Sink in unisex restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM120-BATH-W-HHWA-FD (BLDG 166-7)	Bathroom designated for children under 12 - Sink on left in girls restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Youth Center Buildings 166

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	KB-166-RM120-BATH-W-HHWP-FD (BLDG 166-8)	Bathroom designated for children under 12 - Sink second to left in girls restroom	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM120-BATH-W-HHWC-FD (BLDG 166-9)	Bathroom designated for children under 12 - Sink in middle in girls restroom	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM120-BATH-W-HHWD-FD (BLDG 166-10)	Bathroom designated for children under 12 - Sink second to right in girls restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM120-BATH-W-HHWE-FD (BLDG 166-11)	Bathroom designated for children under 12 - Sink on right in girls restroom	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-166-RM132-RM-UT-FD (BLDG 166-13)	Art Room - Sink used for art projects.	1.8	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	3	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	5	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	10	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	18	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0