

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Play Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	KB-PLAY-WFBA-FD (OPA-1)	Soccer Complex Stands by Faucet - Water fountain at soccer complex	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-WFCA-FD (OPA-2)	Soccer Complex Restroom Building - Water fountain at building with restrooms	2.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-WFCB-FD (OPA-3)	Soccer Complex between restrooms - Water fountain at building with restrooms	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-WFBB-FD (OPA-4)	Soccer Complex Standing Faucet - Water fountain at soccer complex	4.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-1035-WFBA-FD (OPA-5)	Ballfield Bldg 1035 houses restrooms and concession stand - Water fountain on left	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-1035-WFBB-FD (OPA-6)	Ballfield Bldg 1035 houses restrooms and concession stand - Middle water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-1035-WFBC-FD (OPA-7)	Ballfield Bldg 1035 houses restrooms and concession stand - Water fountain on right	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-TRACK-WFBB-FD (OPA-9)	Fountain by Track towards end of pond - Water fountain by track	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-BASKETBALL-WFB- FD (OPA-10)	By basketball court - Water fountain by basketball court	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-TENNIS-WFB-FD (OPA-11)	By tennis court - Water fountain by tennis court	7.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KB-PLAY-156-WFBA-FD (OPA-12)	Fountain at CCD ballfield concession stand - Water fountain near concession stand at baseball field by youth center.	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions November 2014
NSB KINGS BAY Play Areas

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			11/1/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			11/10/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	KB-PLAY-156-WFBB-FD (OPA-13)	Fountain at CCD ballfield concession stand - Fountain designed for disable access	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-PLAY-156-HOSE-FD (OPA-14)	Hose bib at CCD ballfield concession stand - Hose bib on concession stand at ballfield near youth center	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KB-PLAY-156-HOSEB-FD (OPA-15)	Hose bib at CCD ballfield concession stand - Hose bib on concession stand at ballfield near youth center next to OPA-12	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	12	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	2	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	14	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0