

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
Admiral Hartman									
4649-BB1	0.419	DRINKING	19H56401	8/22/2019	NO				
4649-G-RR-S1	1.07	WASHING	19H49601	8/15/2019	NO				
4649-G-RR-S2	0.663	WASHING	19H49602	8/15/2019	NO				
4649-G-RR-S3	0.898	WASHING	19H49603	8/15/2019	NO				
4649-B-RR-S1	0.744	WASHING	19H49604	8/15/2019	NO				
4649-B-RR-S2	0.736	WASHING	19H49605	8/15/2019	NO				
4649-B-RR-S3	0.659	WASHING	19H49606	8/15/2019	NO				
4649-SAC-TOT-S1	0.824	DRINKING	19H49607	8/15/2019	NO				
4649-KITCHEN-S1	0.576	COOKING	19H49608	8/15/2019	NO				