

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
CDC-NBPL-B 377									
R-122-S3	0.323	Drinking	19H58601	8/23/2019	NO				
R-105_S3A	21.8	Drinking	19H58602	8/23/2019	YES				RESAMPLE/RE-TEST
R-105_S3A-2FD	26.3	Drinking	I500-05	9/12/2019	YES	26.3		9/12/2019	REPLACE FIXTURE
R-105_S3A-3OSF	4.55	Drinking	I500-06	9/12/2019	YES		4.55	9/12/2019	REPLACE FIXTURE
R-103-S1	0.962	Drinking	H520-08	8/17/2019	NO				
R-103-S2	0.223	Drinking	H520-09	8/17/2019	NO				
R-104-S1	0.246	Drinking	H520-10	8/17/2019	NO				
R-104-S2	0.686	Drinking	H520-11	8/17/2019	NO				
R-105-S1	2.38	Drinking	H520-05	8/17/2019	NO				
R-105-S2	2.3	Drinking	H520-06	8/17/2019	NO				
R-105-S3	5.48	Drinking	H520-07	8/17/2019	NO				
R106-S1	2.22	Drinking	H520-01	8/17/2019	NO				
R-106_S1A	17.6	Drinking	H520-02	8/17/2019	YES				RESAMPLE/RE-TEST
R-106_S1A-2FD	16.5	Drinking	I500-03	9/12/2019	YES	16.5		9/12/2019	REPLACE FIXTURE
R-106_S1A-3OSF	3.09	Drinking	I500-04	9/12/2019	YES		3.09	9/12/2019	REPLACE FIXTURE
R106-S2	0.44	Drinking	H520-03	8/17/2019	NO				
R106-S3	1.53	Drinking	H520-04	8/17/2019	NO				
OS1	6.08	Drinking	H520-12	8/17/2019	NO				
HB1	2.84	Water Play	H520-13	8/17/2019	NO				
OS2	3.82	Drinking	H520-15	8/17/2019	NO				
HB2	2.32	Drinking	H520-16	8/17/2019	NO				
OS3	6.77	Drinking	H520-18	8/17/2019	NO				
HB3	3.11	Water Play	H520-19	8/17/2019	NO				
BB3	3.66	Drinking	H520-14	8/17/2019	NO				
BB4	0.458	Drinking	H520-17	8/17/2019	NO				
BB5	1.28	Drinking	H521-01	8/17/2019	NO				
BB6	0.278	Drinking	H521-04	8/17/2019	NO				
BB7	1.98	Drinking	H521-07	8/17/2019	NO				
OS4	2.42	Drinking	H521-02	8/17/2019	NO				

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
CDC-NBPL-B 377									
OS5	3.95	Drinking	H521-05	8/17/2019	NO				
HB4	6.1	Water Play	H521-03	8/17/2019	NO				
HB5	5.65	Water Play	H521-06	8/17/2019	NO				
ADMIN-S1	1.6	Drinking	H521-08	8/17/2019	NO				
121-S3	0.718	Drinking	H521-09	8/17/2019	NO				
101-S1	0.46	Drinking	H519-09	8/17/2019	NO				
101-S2	0.465	Drinking	H519-10	8/17/2019	NO				
102-S1	0.36	Drinking	H519-19	8/17/2019	NO				
102-S2	0.563	Drinking	H519-20	8/17/2019	NO				
107-S1	1.68	Drinking	H519-15	8/17/2019	NO				
107-S2	1.2	Drinking	H519-16	8/17/2019	NO				
107-S3	2.66	Drinking	H519-17	8/17/2019	NO				
107-S3A	1.4	Drinking	H519-18	8/17/2019	NO				
108-S1	0.307	Drinking	H519-11	8/17/2019	NO				
108-S1A	0.842	Drinking	H519-12	8/17/2019	NO				
108-S2	1.98	Drinking	H519-13	8/17/2019	NO				
108-S3	0.432	Drinking	H519-14	8/17/2019	NO				
109-S1	0.508	Drinking	H519-05	8/17/2019	NO				
109-S2	0.21	Drinking	H519-06	8/17/2019	NO				
109-S3	0.428	Drinking	H519-07	8/17/2019	NO				
109-S3A	0.482	Drinking	H519-08	8/17/2019	NO				
110-S1	0.451	Drinking	H519-01	8/17/2019	NO				
110-S1A	0.327	Drinking	H519-02	8/17/2019	NO				
110-S2	0.583	Drinking	H519-03	8/17/2019	NO				
110-S3	0.464	Drinking	H519-04	8/17/2019	NO				
111-S1	0.626	Drinking	H518-15	8/17/2019	NO				
111-S2	0.573	Drinking	H518-16	8/17/2019	NO				
111-S3	0.372	Drinking	H518-17	8/17/2019	NO				
111-S3A	1.02	Drinking	H518-18	8/17/2019	NO				

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
CDC-NBPL-B 377									
112-S1	0.509	Drinking	H518-11	8/17/2019	NO				
112-S1A	0.558	Drinking	H518-12	8/17/2019	NO				
112-S2	0.596	Drinking	H518-13	8/17/2019	NO				
112-S3	0.378	Drinking	H518-14	8/17/2019	NO				
113-S1	0.379	Drinking	H518-05	8/17/2019	NO				
113-S2	0.373	Drinking	H518-06	8/17/2019	NO				
113-S2A	0.666	Drinking	H518-07	8/17/2019	NO				
113-S3	0.276	Drinking	H518-08	8/17/2019	NO				
113-S3A	0.463	Drinking	H518-09	8/17/2019	NO				
114-S1A	0.574	Drinking	H518-01	8/17/2019	NO				
114-S2	0.513	Drinking	H518-02	8/17/2019	NO				
114-S2A	0.317	Drinking	H518-03	8/17/2019	NO				
114-S3	0.24	Drinking	H518-04	8/17/2019	NO				
172-Laundry	1.08	Washing	H518-20	8/17/2019	NO				
173-RR-S1	0.358	Washing	H518-19	8/17/2019	NO				
175-Staff-S1	0.25	Drinking	H518-10	8/17/2019	NO				
114-S1	0.224	Drinking	H517-20	8/17/2019	NO				
115-S1	0.311	Drinking	H517-15	8/17/2019	NO				
115-S2	0.685	Drinking	H517-16	8/17/2019	NO				
115-S2A	1.64	Drinking	H517-17	8/17/2019	NO				
115-S3	0.419	Drinking	H517-18	8/17/2019	NO				
115-S3A	0.373	Drinking	H517-19	8/17/2019	NO				
116-S1	2.46	Drinking	H517-10	8/17/2019	NO				
116-S1A	1.86	Drinking	H517-11	8/17/2019	NO				
116-S2	1.28	Drinking	H517-12	8/17/2019	NO				
116-S2A	2.81	Drinking	H517-13	8/17/2019	NO				
116-S3	1.44	Drinking	H517-14	8/17/2019	NO				
117-S1	2.87	Drinking	H517-07	8/17/2019	NO				
117-S2	1.35	Drinking	H517-08	8/17/2019	NO				

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
CDC-NBPL-B 377									
117-S3	2.53	Drinking	H517-09	8/17/2019	NO				
118-S1	0.585	Drinking	H517-04	8/17/2019	NO				
118-S2	1.02	Drinking	H517-05	8/17/2019	NO				
118-S3	1.15	Drinking	H517-06	8/17/2019	NO				
119-S1	0.576	Drinking	H517-01	8/17/2019	NO				
119-S2	2.13	Drinking	H517-02	8/17/2019	NO				
119-S3	0.447	Drinking	H517-03	8/17/2019	NO				
120-S1	0.528	Drinking	H516-18	8/17/2019	NO				
120-S2	1.22	Drinking	H516-19	8/17/2019	NO				
120-S3	0.487	Drinking	H516-20	8/17/2019	NO				
121-S1	0.951	Drinking	H516-16	8/17/2019	NO				
121-S2	1.52	Drinking	H516-17	8/17/2019	NO				
121-S3	0.718	Drinking	H521-09	8/17/2019	NO				
122-S1	0.316	Drinking	H516-14	8/17/2019	NO				
122-S2	0.616	Drinking	H516-15	8/17/2019	NO				
122-S3	0.323	Drinking	H586-01	8/23/2019	NO				
123-RR-S1	0.994	washing	H516-12	8/17/2019	NO				
125-S1	0.588	Drinking	H516-13	8/17/2019	NO				
127-ktchn-S1	1.55	Cooking	H516-06	8/17/2019	NO				
127-ktchn-S2	0.374	Cooking	H516-07	8/17/2019	NO				
127-ktchn-S3	0.464	Cooking	H516-08	8/17/2019	NO				
127-ktchn-S4	2.44	Cooking	H516-09	8/17/2019	NO				
127-ktchn-S5	1.5	Cooking	H516-10	8/17/2019	NO				
127-ktchn-S6	1.59	Cooking	H516-11	8/17/2019	NO				
R-141-ISO-S1	25.1	washing	H516-05	8/17/2019	YES				Re-Sample/Re-Test
141_ISOLATN_S1-2FD	18.3	washing	I500-01	9/12/2019	YES	18.3		9/12/2019	REPLACE FIXTURE
141_ISOLATN_S1-30SF	1.38	washing	I500-02	9/12/2019	YES		1.38	9/12/2019	REPLACE FIXTURE
145-RR-S1	1.48	washing	H516-03	8/17/2019	NO				
146-RR-S1	0.386	washing	H516-04	8/17/2019	NO				

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
CDC-NBPL-B 377									
BB1	0.405	Drinking	H516-01	8/17/2019	NO				
BB2	0.573	Drinking	H516-02	8/17/2019	NO				